

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/SZ/2020/ 175

Dated: 7/12/2020

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Burger King India Private Limited running at Ground Floor** of a building located at Shop No.- SP- 4G & SP- 5G, GF, Shadipur Metro Station, New Delhi-110008, owned/occupied by M/s Burger King India Private Limited. The restaurant was inspected by the officer concerned of this department on 26.11.2020 in presence of Sh. Avinash Sharma (Branch Manager) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly (restaurant) at **ground floor only** with effect from 7/12/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 7/12/2020 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Deputy Health Officer, North Delhi Municipal Corporation, Karol Bagh Zone, Anand Parbat, New Delhi- 110005.
2. The Joint. Commissioner of Police (Lic.), 1st floor, Police Station Defence Colony, New Delhi.
3. The Owner / Occupier, M/s. Burger King India Private Limited, Shop No.- SP- 4G & SP- 5G, GF, Shadipur Metro Station, New Delhi-110008.

INSPECTION REPORT

1. Name & address of the building : M/s. Burger King India Pvt. Ltd., Shop No. SP- 4G & SP-5G, Shadipur Metro Station, New Delhi- 110008.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : N/A.
6. Date of inspection : 26.11.2020
7. Name of the Inspecting Officers : D.B. Mukherjee, Div. Officer (SW) & P.V. Rathee, Asstt. Div. Officer (SRD)
8. Name and designation of officers from the building side : Sh. Avinash Sharma (Manager)
9. Year of Construction : 2005
10. Applicant's letter No. : Online application ID 2020111808523 dated 18.11.2020

The said restaurant is running at Ground Floor of Shadipur Metro Station building.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as UBBL / NBC-IV	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	N/A	N/A	Restaurant running at GF only
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	N/A	N/A	Restaurant running at GF only
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0, 1.5 mts.	2.0, 1.5 mts	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• ground floor	12 a/c per hour	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	06	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

N-8

6	First-Aid Hose Reels.	Provided and Maintained by DMRC		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Entire Restaurant Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants	Provided and Maintained by DMRC		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Required Required Required	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements.	Provided and Maintained by DMRC		
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	--- 1800 LPM 60 mts. 02 180 LPM 60 mts 1800 LPM 60 mts Required Required ----- N/A N/A N/A N/A	--- Provided Provided Provided Provided Provided N/A Provided Provided ----- N/A N/A N/A N/A	--- MR MR MR MR MR MR N/A MR MR ----- N/A N/A N/A N/A
14	Captive Water Storage for fire fighting.	Provided and Maintained by DMRC		
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50,000 lts N/A N/A N/A 20,000 lts	100000 lts Provided Provided Provided Provided	MR N/A N/A N/A MR

N-9

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act-2007 & Rules 2010. DFA is put up for approval & signature please.



[Signature]
 03/12/2020
 Signature of the Inspecting Officer
 D.B. Mukherjee
 Divisional Officer, (SW)

[Signature]
 2/12/2020
 Signature of the Inspecting Officer
 P.V. Rathee
 Asstt. Div. Officer (SRD)

By cfo (s2) *[Signature]*

C/F.O.

[Signature]
 4/12

[Signature]
 3/12/2020

FF PLS

DD/SW

Put up f.r. letter pl

ADD (PN)

[Signature]
 07/12/2020