

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/2020/NDZ/172

Dated : 07/12/2020

FIRE SAFETY CERTIFICATE

Certified that the "MY Restaurant" located at 5136, Pahar Ganj, New Delhi comprises of **Basement + Ground floor, Basement (Used for storage), Ground floor (Restaurant)** was granted FSC by this department vide letter No.F6/DFS/MS/EH/2017/1210 dated 14/08/17. The premises was re-inspected by the officer concerned of this department on 01/12/20 in the presence of **Mr. Rajendra Kumar (Owner)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D Restaurant running at Ground floor only** with effect from -----for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 07/12/2020 at New Delhi by.



(S.K.Tomar)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony, New Delhi ...Online ID no. 2020112208603 date 22/11/20.
2. The Medical Officer of Health,
Health Department, NDMC,Civic Centre, New Delhi.
3. The Manager,
"MY Restaurant" located at 5136, Pahar Ganj, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

- | | |
|--|--|
| 1. Name & address of the building | My Restaurant, 5136, Pahar Ganj, New Delhi |
| 2. Type of occupancy:- | Assembly Building Group-D
Basement + Ground floor
Basement (storage) & Ground floor Restaurant |
| 3. Type of case:- | Renewal |
| 4. Details of previous FSC:- | F6/DFS/MS/EH/2017/1210 dated 14/08/17 |
| 5. Fire safety directives No.- | N/A |
| 6. Date of inspection:- | 01/12/20 |
| 7. Name of the inspecting officer:- | Sh. Ravinder Singh (ADO/CC)
Sh. Rajindra Atwal (DO (CD) |
| 8. Name & designation of officer
From the building side:- | Sh. Rajendra Kumar (Owner) |
| 9. Year of construction:- | |
| 10. Applicant's letter No:- | Online ID no. 2020112208603 date 22/11/20
Old renewal |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	N/A	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A Gr. Floor
	2. Basements	01	01	MR
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	1 mtr.	1.10 mtr.	MR(old Case)
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	06 Nos.	MR



N/20


	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	450 LPM	450 LPM	MR
	b) Head of main pump	40 mtr.	40 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	250 LPM	250 LPM	MR
	e) Jockey pump head	40 mtr.	40 mtr.	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	5,000 ltr.	5,000 ltr.	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.			
16.	Provision of Lifts.	Required	Provided	MR
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/EH/2017/1210 dated 14/08/17renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer



Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Sy. CFO (CD2)

Signature of Inspecting officer



Sh. Ravinder Singh
Designation : ADO (CC)

S. Kumar
7/12/2020

M.S./Cell

uploaded

well

(FR)

08/12/20