

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2020/ 506

Dated: 07/12/2020

FIRE SAFETY CERTIFICATE

Certified that the Residential Blocks No. 03, 07, 08 & 09 [(04 Nos) excluding basement] Type-IV Quarters, GPRA Complex, Kidwai Nagar (East), New Delhi-110023, comprised of 3 Tier Basement, Ground Floor + 14 Upper Floors (All 04 Blocks) owned / occupied by NBCC (India) Limited, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 01/12/2020 in the presence of Mr. Mahabir Singh (DGM) and found that the building / premises is fit for the occupancy class "Residential" (Group-A) with effect from 07/12/2020. for a period of five years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/12/2020 at New Delhi by.

(Ajul Garg)
Director

Delhi Fire Service

Copy to :-

1. Sh. A.K. Sharma, CGM (Engg.), Project Office: Redevelopment of Kidwai Nagar (East), Ground Floor, Office Block No.-4, Along Ring Road, East Kidwai Nagar, New Delhi-110023.
2. The Executive Engineer (Bldg.), New Delhi Municipal Council, Palika Kendra, New Delhi-110001.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
7. This Fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
8. This certificate cannot be treated in any case for regularizations of unauthorized construction.
9. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate. six months prior to its expiry".
10. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.
11. Basement underneath of these Residential Blocks shall not be occupied or used till the receipt of its clearance / FSC from DFS as undertaken by NBCC vide its letter No. NBCC/EKN-Type IV/CGM/DFS/2020/1237 date 26/10/2020.

INSPECTION REPORT

1. Name & address of the building: Residential Blocks No. 03, 07, 08 & 09 [(04 Nos) excluding basement] Type-IV Quarters, GPRA Complex, Kidwai Nagar (East), New Delhi-110023.
2. Type of Occupancy : Residential (Group-A)
3. Building Comprised of : 3 Tier Basement, Ground Floor + 14 Upper Floors (All 04 Blocks)
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives Letter No. : F6/DFS/MS/BP/2013/01 dated 02/01/2014
7. Date of inspection : 01/12/2020
8. Name of the Inspecting Officer : A.D.O. (S.J.) & Dy.C.F.O. (S.Z.)
9. Name and designation of Officer from the building side : Sh. Mahabir Singh (DGM)
10. Year of Construction : 2018
11. Applicant's letter No. : - NBCC/EKN-TYPE IV/CGM/DFS/2020/1430 dated 27/11/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL-2016 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 No. (each block)	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.35 Mtr.	Blk-3 (1.40m & 1.37m) Blk-7(1.42m & 1.40m) Blk-8(1.36m & 1.40m) Blk-9(1.36m & 1.36m)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required in Lift well	Provided in Lift well Natural Ventilation in Staircase	MR
	d. No of continuous staircase to terrace	2 No. (each blk)	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.00mtr	1.00 mtr	MR
3.	Compartmentation			
	In each residential Block No. 03,07,08 & 09			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door.	Required	Provided	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	In each residential Block No. 03,07,08 & 09			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural Ventilation	MR



5.	Fire Extinguishers	In each residential Block No. 03,07,08 & 09		
	• Total numbers	30 (Each Blk)	60 (Each Blk)	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R
6.	First – Aid Hose Reels	In each residential Block No. 03,07,08 & 09		
	• Total numbers on each floor	One at each floor	One at each floor	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA (In each residential Block No. 03,07,08 & 09)	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System (In each residential Block No. 03,07,08 & 09)			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants (In each residential Block No. 03,07,08 & 09)			
	• Size of riser/down-comer	100 mm	150 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants (In each residential Block No. 03,07,08 & 09)			
	• Total number of hydrants	1	1	MR
	• Hose Box	1	1	MR
13.	Pumping Arrangements (In each residential Block No. 03,07,08 & 09)			
	• Ground Level	Common Pump Room at B-2 Level		
	• Discharge of main pump	Hyd. & Sprinkler (H&S) 2850 LPM (Each) Water Curtain (WC): 2 of 2280 LPM	Hyd. & Sprinkler (H&S) 2850 LPM (Each) Water Curtain (WC): 2 of 2280 LPM	MR
	➤ Head of main pump	H&S: 90m (each) WC: 45m (each)	Provided	MR
	➤ Number of main pumps	4	Provided	MR
	➤ Jockey pump out put	2 of 280 LPM	Provided	MR
	➤ Jockey pump head	H&S 90m (Each)	Provided	MR
	➤ Standby Pump out put	2850 LPM	Provided	MR
	➤ Standby Pump Head	90m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR

	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting (In each residential Block No. 03,07,08 & 09)			
	• Underground tank capacity	2,00,000 lts	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10000 Ltr	10,000 Ltrs.	MR
15.	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts (In each residential Block No. 03,07,08 & 09)			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided (DG)	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room (Provided at entrance level of Tower No.6)			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- Shortcomings issued by this department vide letter No F6/DFS/MS/Resd./2020/SZ/2812 dated 18/11/2020 have been fully complied.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

Signature of the Inspecting Officer
Name : Sunil Chawdhary
Designation : Dy.C.F.O. (S.Z.)

C.F.O. (on day off)
Director/2/12/20

2/12/20
3/12