

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2020 / 52(EH/178)

Dated: 11/12/2020

FIRE SAFETY CERTIFICATE

Certified that the M/s **Havemore Restaurant Saket** located at Shop No. 12 & 12a, Ground Floor MGF Metropolitan Mall, Saket, New Delhi-110017 is running at ground floor in the building comprised of 02 tier basement, Ground and 07 upper floors owned/ occupied by M/s **Havemore Restaurant Saket** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 25.11.2020 in the presence of **Sh. Vaibhav Bajaj, Owner** and that the building/ premise is fit for occupancy **Class Assembly for ground floor only** with effect from 11/12/2020 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on11/12/2020..... at New Delhi by


(Atul Garg)
Director

Ph-011-23414000

Copy to:-

1. M/s Havemore Restaurant Saket, Shop No. 12 & 12a, Ground Floor, MGF Metropolitan Mall, Saket, New Delhi-110017
2. The Addl. CP/Lic. , 1st floor, Defence Colony, Delhi

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/S

INSPECTION REPORT

1. Name & address of the building : M/s Havemore Restaurant Saket, Shop No. 12 & 12a, Ground Floor
MGF Metropolitan Mall, Saket, New Delhi-110017.
2. Type of Occupancy : Assembly (Ground floor only) 02 Tier Basement, Ground + 07 upper floors
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : NBC Part IV.
6. Date of inspection : 25.11.2020
7. Name of the Inspecting Officers : ADO (BCP)
8. Name and designation of officers
from the building side : Mr Vaibhav Bajaj
9. Year of Construction : 2006
10. Applicant's letter No. : Online ID No. 2020093007358 dated 07.10.2020

	Minimum Standards on fire prevention and fire safety U/R 33	UBBL / NBC Requirement	Provided at site	Remarks MR/NMR	
1	Access to building (F.6/DFS/MS/2019/Mall/SZ/1371 dated 07/10/2020)				
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6m	Provided	MR	
		NA	NA	NA	
		NA	NA	NA	
2	Number, Width, Type & Arrangement of Exits Common with Mall				
	a. Number of staircases				
		<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	b. Width of staircases				
		<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
	c. Protection of exits	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
			NA	NA	NA
			NA	NA	NA
	d. No. of continuous staircases to terrace				
	e. Width of Corridor				
	f. Door Size	2m & 1.50m	2.00m & 1.50m	MR	
	3	Compartmentation. Common with Mall			
		<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA

2/6

	<ul style="list-style-type: none"> Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Dampers 	NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	06nos	06nos	MR
	<ul style="list-style-type: none"> Types 	ABC/Co2	ABC-6	MR
	<ul style="list-style-type: none"> ISI marking 	Yes	Yes	MR
6	First-Aid Hose Reels. Common with Mall			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system. Common with Mall			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants Common with Mall			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR

12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
13	Pumping Arrangements. Common with Mall			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	450lpm	450 lpm	MR
		40m	Provided	MR
Required		Provided	MR	
Required		Provided	MR	
14	Captive Water Storage for fire fighting. Common with Mall			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		20,000 ltr	20,000 ltr	MR
Required	Provided	MR		
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
Required	Provided	MR		
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			

	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Ru
02/11/2022

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation:- ADO/BCP

BSISO - on leave
24/10/22 *[Signature]*
4/12

C.F.O.
[Signature]
4/12

Director
[Signature]

[Signature]

Director
[Signature]
4/12

As approved, F.S. letter is being for your signature
oi
1/11/22



Fse uploaded on MNA online portal.
[Signature]
14/11/2022