

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/CGHS/2020/NDZI/515

Dated: 10/12/20

FIRE SAFETY CERTIFICATE

Certified that the Mansara Co-operative Group Housing Society Limited, Plot 09 , Vasundhara Enclave, Delhi-96, comprised of two blocks stilt/ground plus seven upper floors. The building was issued NOC by this department vide Letter no. F.6/DFS/MS/CGHS/98/1632 dated 21/08/98. The residential building was re-inspected by the officer concerned of this department 13/10/2020 in the presence of Mr. Bal Krishan (Tresurer) and found that the building have deemed complied with the fire prevention and fire safety requirement in accordance with the rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class A "Residential" with effect from 10/12/20..... for a period of five years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....10/12/20.....at New Delhi by

(Atul Gang)
Director

Delhi Fire Service

To,
The Secretary,
Mansara Co-operative Group Housing Society Limited,
Plot 09 , Vasundhara Enclave, Delhi-96

O/c
f

1. Name & address of the building : Mansara Co-operative Group Housing Society Limited, Plot -09, Vasundhara Enclave, Delhi-110096.
2. Building is comprised of : Stilt/ground+7 upper floors
3. Type of Occupancy : Residential
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/CGHS/98/1632 dated 21/08/98
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 13/10/2020
8. Name of the Inspecting officers : DO F. Brown, Dy. CFO, Sunil Chaudhary
9. Name and designation of officer from the building side : Mr. Bal Krishan (Treasurer)
10. Year of construction : 1993
11. Applicant's letter No : Nil dated- 16/09/2020


Sr N	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement as per guidelines	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr.	18mtr.	MR
	• Gate width	4.5 mtr.	5 mtr.	MR
	• Width of internal road	08 m	06 m, 8m	MR Old accepted
2	Numbers, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor Each block	02 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor each block	1.15&.75 m	1.15&.75 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 Nos.	01 Nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	30a/c per hour	N/A	N/A
	• Upper floor	30a/c per hour	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers	35 Nos.	Provided	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-Aid-Hose Reels. Each block			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 no.	Provided	MR
		30 mtr.	Provided	MR
		05 mm	Provided	MR
7	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants each block			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose box 	100 mm	Provided	MR
		01 No.	Provided	MR
		01 No.	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	04 Nos.	Provided	MR
		04 Nos.	Provided	MR
13	Pumping Arrangements.			
	Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump each block Head of the pump Power supply Auto Starting of pump 	900 LPM	Provided	MR
		60 M	60 M	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,00,000 Ltrs.	1,00,000 Ltrs.	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltrs.	10,000 Ltrs. Each block	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication in lift car • Firemen's grounding switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. Earlier issued shortcoming letter vide no.F6/DFS/MS/CGHS/2000/588 Dated 27/03/2000 which is rectified.


Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules. The Building was issued NOC vide Letter no. F.6/DFS/MS/CGHS/98/1632 dated-21/08/98 renewal under the rule 33 of the Delhi Fire Service 2010 is recommended.

DY. C.F.O./MD-21

 13/7

C.F.O.

Re speak


 Signature of the Inspecting Officer
 Name- F. Brown
 Designation- DO (ED)


 Defo [unclear]
 12/7
