

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/2020/cin/516

Dated: 11/12/2020

FIRE SAFETY CERTIFICATE

Certified that M/s. INOX Leisure Limited (Audi I to IV), located at Satyam Building Patel Nagar, New Delhi, is running on ground to third floor of a building comprised of basement, ground plus four upper floors was granted FSC/NOC by this department vide letter No. F.6/DFS/MS/2017/Cinema/1754 dated 07.12.2017 and was re-inspected by the officer concerned of this department on 26-11-2020 in presence of Sh. Vinay Kaushik (Manager) and found that the said cinema building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and that the building/premises is fit for occupancy class assembly (cinema) with effect from 11/12/2020 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/12/2020 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. District Magistrate (West), Old Middle School Building Complex, Rampura, Delhi-35
2. The Joint. C.P. (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.
3. The Manager, INOX Leisure Ltd. (I to IV), Patel Nagar, New Delhi.

However the following directives must be strictly adhered to:

- a. All the fire fighting arrangements as provided in the cinema building shall always be kept in good repair at all times as seen during inspection.
- b. All the employees shall be acquainted with the use & maintenance of fire protection arrangements provided in the cinema building.
- c. Means of escape shall not be kept blocked or bolted from outside & shall be easily open able in case of emergency.
- d. The fire suppression/protection arrangement provided in the premises are the minimize losses if maintained properly.
- e. Any loss of property/ life due to nonfunctional of fire safety measures/ equipments shall be responsibility of management solely.
- f. Cinema slides providing information on fire protection arrangements and means of escape shall be shown before the commencement of each cinema show.

1. Name & address of the building : INOX Leisure Limited, Satyam Building, Patel Nagar, New Delhi.
 2. Type of Occupancy : Assembly
 3. Type of Case : Renewal
 4. Details of previous NOC : F.6/DFS/MS/2017/Cinema/1754 dated 07.12.2017
 5. Fire Safety directives letter No : F.6/DFS/MS/Cinema/BP/2001/770 dated 08.05.2001
 6. Date of inspection : 26.11.2020
 7. Name of the Inspecting Officers : D.B. Mukherjee, Div. Officer (SW) & P.V. Rathee, Asstt. Div. Officer (SRD)
 8. Name and designation of officers from the building side : Sh. Vinay Kaushik (Manager)
 9. Year of Construction : 2001
 10. Applicant's letter No. : Online Email ID pankaj.kanotra@inoxmovies.com
- Dated 17.11.2020

Inox Cinema is running at ground to third floor of a building comprised of basement, ground and four upper floors.

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	04 Nos.	Provided	MR
	• Basements	02 nos. & 02 Ramps	Provided	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	02 mts (03), 1.20 mts (01)	Provided	MR
	• Basements	1.25 each	Provided	MR
	c. Protection of exits	-----	-----	-----
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	02 Nos.	Provided	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	Old case	1.85 mts. each	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR

	<ul style="list-style-type: none"> Total numbers Types IS marking 	69 nos. ABC, Water, CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	03 Nos. 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/Heat Ground floor Near Staircases Required Entire Building	Provided smoke & beam detector. Provided Provided D.G. set (380, 250 KVA) Provided	MR MR MR MR MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required Required Required	Provided Provided Provided	MR MR MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm Basement to GF-04 each, FF to SF- 03 each Basement to GF-04 each, FF to SF- 03 each	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	07 Nos. 07 Nos.	Provided Provided	MR MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	--- 2850 LPM each 60 mts. each 02 Nos. 180 LPM 60 mts. 2850 LPM 60 mts. Required Required ---- N/A N/A Required N/A	----- Provided Provided Provided Provided Provided Provided Provided Provided Provided ----- N/A N/A Provided N/A	----- MR MR MR MR MR MR MR MR MR ----- N/A N/A MR N/A


14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	2,00,000 lts.	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
		30,000 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	CO ₂ fire extinguishers are provided in elect. Panels.	MR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/2017/Cinema/1754 dated 07.12.2017, renewal under the Delhi Fire Service Act- 2007 & Delhi Fire Service Rules- 2010, is recommended.

DFA is put up for approval & signature please




 Signature of the Inspecting Officer
 D.B. Mukherjee
 Divisional Officer, (SW)


 Signature of the Inspecting Officer
 P.V. Rathee
 Asstt. Div. Officer (SRD)

Dy cfo (s2)

C.F.O.

devoid to dy.