

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2020/ 557

Dated: 17/12/2020

FIRE SAFETY CERTIFICATE

Certified that the **A-One International Public School, B-Block, Inder Enclave Phase-I, Delhi-110086**, comprised of **Single block, Basement + Ground + Three Upper Floors** owned/occupied by **A-One International Public School** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on dated **19.10.2020** in the presence of **Mr. Dalbir (Manager)** and that the building/ premise is fit for occupancy Group B Educational with effect from **17/12/2020**..... for a period of **three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.**

Issued on 17/12/2020 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:

1. The Principal, A-One International Public School, B-Block, Inder Enclave Phase-I, Delhi-110086.
 2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054
- Conditions for validity of Fire Safety Certificate;**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry”.
7. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form ”K” is available on http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building ; A-One International Public School, B-Block, Inder Enclave Phase-I, Delhi-110086.
2. Type of Occupancy : Educational /NBC Part IV
3. Type of Case : New Case (B + G + 03 Upper floor)
4. Details of Previous NOC : N/A (Old NOC F.6/DFS/MS/School/WZ/2020/283 dated 14.08.2020)
5. Fire Safety directives letter No N/A B+G+01
6. Date of inspection : 19.10.2020
7. Name of Inspecting Officer : ADO (Rohini)
8. Name and designation of officers
From the building side : Sh. Dalbir (Manager)
9. Year of Construction : 2010 & 2014
10. Applicant's letter No. : Online mail dated 27.10.2020

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Part IV | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|-----------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | Accessible | 12 mtr | MR |
| | • Gate width | Accessible | 5.0 mtr | M.R |
| | • Width of internal road | 05 mtr | 06 mtr | MR |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | d. Number of staircases | NA | NA | NA |
| | • Upper Floors | 02 | 03 | MR |
| | • Basements | 02 | 02 | MR |
| | e. Width of staircases | 1.50 mtr | 2 x 1.50 mtr & 1.25 m | MR |
| | • Upper Floor | 1.50 mtr | 1.25 & 1.50 mtr | MR (Old Case) |
| | • Basements | NA | NA | NA |
| | f. Protection of exits | NA | NA | NA |
| | Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | 02 | 02 | MR |
| | e. Width of Corridor | Required | 2.80 mtr | MR |
| | f. Door Size | 1 mtr | 1.05 mtr | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke Management System | | | |
| | • Basements | 30 a/c per hour | Natural ventilation | MR |
| | • Upper floors | 12 a/c per hour | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 16 No's | 16 No's | MR |
| | • Types | ABC/CO2 | ABC 16 | MR |

| | | | | |
|-----|--|---|--|--|
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 01 30 m 5 mm | Provided Provided Provided | MR MR MR |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA | NA NA NA NA NA | NA NA NA NA NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling | Required NA NA | Provided NA NA | MR NA NA |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA NA | NA NA | NA NA |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | NA NA NA NA NA NA NA NA NA 900 LPM 40 m Required Required | NA NA NA NA NA NA NA NA NA Provided 40 m Provided Provided | NA NA NA NA NA NA NA NA NA MR MR MR MR |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | NA NA NA NA 15,000 ltr | NA NA NA NA 15,000 ltr | NA NA NA NA MR MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | NA NA NA NA NA | NA NA NA NA NA | NA NA NA NA NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> Total Area | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 19 | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | | | |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Handwritten Signature]

Signature of the Inspecting Officer
 Name **Ajay Kumar Sharma**
 Designation **ADO (Rohini)**

Bocaneg *[Signature]* 03/12/2020

By ~~CFP~~ CFO (WZ) - on leave

CFP *[Signature]* 28/12

~~*[Signature]*~~ 03/12/20

Date of 18/12/20
 19/10/2020, as he on duty on that day P/S chg

[Signature] 9/12/20

[Signature] 27/12/20

DCFI/WL

~~*[Signature]*~~
[Signature] 11/12/2020

App/R

FI letter is put up for need
 manual and signature please

