

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2020/ 575

Dated: 21/12/2020

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Boys/Girls Middle School, Pocket-D, Sector-16, Rohini, Delhi-110089**, comprised of **Ground + One Upper Floor** owned/ occupied by **Govt. Boys/Girls Middle School** have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **21.10.2020** in the presence of **Smt. Nirmla Soni (Vice Principal)** and that the building/ premise is fit for occupancy Group B Educational with effect from **21/12/2020**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 21/12/20 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:

1. The Principal, Govt. Boys/Girls Middle School, Pocket-D, Sector-16, Rohini, Delhi-110089
2. The Director of Education, Old Secretariat, Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

1. Name & address of the building : Govt. Boys/Girls Middle School, Pocket-D, Sector-16, Rohini, Delhi-110089
2. Type of Occupancy : Educational
3. Type of Case : New Case (One Block, Gr. + 1 upper floors)
4. Details of Previous NOC : Nil
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 21.10.2020
7. Name of Inspecting Officer : A.K.Sharma ADO (Rohini)
8. Name and designation of officers
From the building side : Smt. Nirmla Soni (Vice Principal)
9. Year of Construction : 2007
10. Applicant's letter No. : GGMS/Sec-16/Rohini/2309 dated 12.10.2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6m	6m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	02	MR
	• Upper Floors	N/A	N/A	N/A
	• Basements			
	b. Width of staircases	1.5m	2 X 1.5m	MR
	• Upper Floor	N/A	N/A	N/A
	• Basements			
	c. Protection of exits	N/A	N/A	N/A
	Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	2.45m	MR
	e. Width of Corridor	1.0m	1.05m	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	06nos	06nos	MR
	• Types	ABC/Co2	ABC-06	MR
	• ISI marking	ISI marking	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor		N/A	N/A
	• Length of hose reel hose		N/A	N/A
	• Nozzle diameter		N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detectors		N/A	N/A
	• Location of Main Panel		N/A	N/A
	• Location of Repeater Panel		N/A	N/A
	• Alternate source of power		N/A	N/A

8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• Ground & Upper Floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

MU

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under Directorate of Education circular 2011 is recommended for issuance of FSC.

Ajay Kumar Sharma
Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Dy. CFO (WZ)

[Signature]
28/10/2020

CFO 'A' at M9 for information and advice M.

[Signature]
28/10/2020

[Signature]

What is at 'A', 9 dm not able to v/s Pls shh

[Signature]
28/10/2020

[Signature]

width of the corridor is required but what is required width is not mentioned, and it is similar at M3 chug shant

[Signature]
OK

[Signature]
28/10/2020

[Signature]
28/10/2020

