

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F.6/DFS/MS/EH/2020/SZ/ 181

Dated: 17/12/2020

FIRE SAFETY CERTIFICATE

Certified that M/s Haldiram Marketing Pvt. Limited situated at P. No. 15, First Floor, Community Centre, New Friends Colony, New Delhi-110025, building comprised of basement (storage only), ground plus two upper floors but the restaurant running at ground, first & second floor was issued NOC by this department vide letter No. F6/DFS/MS/EH/2008/2607 dated 25/02/2008 & F6/DFS/MS/2010/2607 dated 07/09/2010. The premise was re-inspected by the officer concerned of this department on 14/12/2020 in the presence of Sh. Ashafaq (Sr. Manager) and found to have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 that the premises is fit for occupancy class "Group-D Assembly" with effect from 17/12/2020 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/12/2020 at New Delhi by



(Sunil Chowdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, South Delhi Municipal Corporation, Central Zone, Shiv Mandir Road, Lajpat Nagar, New Delhi-110024
2. Sh. Sanjeev Yadav, M/s Haldiram Marketing Pvt. Limited at P. No. 15, First Floor, Community Centre, New Friends Colony, New Delhi-110025

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. Basement shall be used strictly in accordance with the provisions of BBL
5. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building.	M/s Haldiram Marketing Pvt. Limited, P. No. 15, First Floor, Community Centre, New Friends Colony, New Delhi-110025		
2	Type of Occupancy	Group-D, "Assembly" (Eating House)		
3	Building Comprised of	Basement, Ground plus two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2008/2607 Dt. 25/02/2008 (G/Floor) F6/DFS/MS/2010/2607 Dt. 07/09/2010 (1 st +2 nd floor)		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	14-12-2020		
8	Name of the Inspecting Officers	Avtar Singh ADO (MR)		
9	Name & Designation of Officers from the building side	Sh. Ashafaq (Sr. Manager)		
10	Year of construction	1979	Restaurant running at Ground + two upper floors. Basement is used for storage only.	
11	Applicant letter No.	Online ID No. 202111608478 dated 17/11/2020		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL / NBC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6m	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	2 Nos	2 Nos Provided	MR
	➤ Basement floor.	2 Nos	2 Nos Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.5m & 1.25m	2m & 1.5m	MR
	➤ Basement floor	1.25m each	1.80m & 1.30m	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	Two	Provided	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	2 Exits	1.50 & 1.40m	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	30 ACPH	NA	NA
	• Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	12 Nos	MR
	• Types	ABC/CO ₂ /W.CO ₂	ABC, W.CO ₂ & CO ₂	MR
	• ISI Marking	Required	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors. Sprinkler above false ceiling 	N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		01 No	01 No	MR
		01 No	01 No	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	450 LPM	900 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		10,000 Lts	20,000 Lts	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

Covered Area of the Establishment : 176.40 m²
 No of Covers/Seats : 176.4 ÷ 1.8 = 98 Persons
 Height of the Building : 12m

The Fire protection systems provided in the building/premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/EH/2008/2607 dated 25/02/2008 & F6/DFS/MS/2010/2607 dated 07/09/2010, renewal under Rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

(Signature)
15/12/2020

Signature of the Inspecting Officer
 Name: Avtar Singh
 Designation: ADO (MR)

DO (SD)

(Signature)
15/12/2020 F.F. please.

DeFO (S2)
(Signature)
16/12

FT letter is put up for sign. please.

DCFO (S2)
(Signature)
17/12
M.S. ull

(Signature)
17/12/2020