

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/SZ/2020/ 539

Dated: 07/12/2020

FIRE SAFETY CERTIFICATE

Certified that J.D. Tytler School located at R-Block, New Rajendra Nagar, New Delhi- 110060 comprised of basement, ground plus three upper floors was granted Fire Safety Certificate by this department vide letter NO F.6/DFS/MS/School/2017/SZ/1363 dated 15.09.2017. The school buildig was re-inspected by the officer concerned of this department on 17.11.2020 in presence of Mr. J. G. Babbar, Manager of the school and found that the School management have complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the school building is fit for occupancy class "Educational" with effect from _____ for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions printed overleaf under rule 38 of Delhi Fire Service Rules-2010.

Issued on 07/12/2020 at New Delhi by.

(SUNIL CHAUDHARY)
Dy. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Principal, J.D. Tytler School, R-Block, New Rajendra Nagar, New Delhi- 110060.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

1. Name & address of the building : J.D. Tytler School, R-Block, New Rajender Nagar, New Delhi- 110060.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2017/SZ/1363 dated 15.09.2017
5. Fire Safety directives letter No : N/A
6. Date of inspection : 17.11.2020
7. Name of the Inspecting Officers : P.V.Rathee , Asst. Div. Officer (SRD)
8. Name and designation of officers
from the building side : Mrs. J.G.Babbar, Manager
9. Year of Construction : 1985-86
10. Applicant's letter No. : Nil dated 22.10.2020

J.D. Tytler school is comprised of basement, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	Required	Provided from two sides	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	04 Nos.	Provided	MR
	• Basements	03 Nos.	03 Nos.	MR
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt	2.47, 1.50, 1.47 mts	MR
	• Basements	1.5 mts or less & 0.75 mt	1.48, 1.47, 1.50 mts.	MR
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5	Provided	MR
	h. Door Size	1.0 mt.	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Natural ventilation provided	MR

16 Provision of Lifts.		Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18 Refuge Area.				
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19 Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

In view the substantial compliance of minimum standards on fire prevention and fire required under the rules, it is recommended to ~~grant~~ ^{renew the} certificate under Delhi Fire Service 2007 & Rules 2010.

DFA is put up for approval & signature please

RM 25/11/2020

Signature of the Inspecting Officer
(P.V.Rathe) Asst. Div. Officer, (SRD)

D.P. (SW)

K. Gupta
26/11/2020

Dy CFO (S/2)

F. T. please

A.O. (S.R.D.)

Sis, F.T. Letter is sent for sign. please

D.C.F.O (S/2)

B 4/12