

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F.6/DFS/MS/School/2020/SZ/ 566

Dated: 18/12/2020

FIRE SAFETY CERTIFICATE

Certified that the **N.P.Co-ed Primary School**, Kaka Nagar, New Delhi-110003 comprised of ground plus one upper floor owned/occupied by New Delhi Municipal Council was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2017/1359 dated 13/09/2017. The premises was re-inspected by officer concerned by this department on 10/12/2020 in the presence of Mr. Hamid Ali (Asstt. Tacher) of the school and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with Circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and that the building / premises is fit for occupancy class "**Education Building**", as above with effect from 18/12/2020..... for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/12/2020 at New Delhi by


(Sunil Choudhary)
Dy. Chief Fire Officer
Delhi Fire Service

ok AL

Copy to: -

1. The Principal, N.P.Co-ed Primary School, Kaka Nagar, New Delhi-110003
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	N.P.Co-ed Primary School, Kaka Nagar, New Delhi-110003.		
2	Type of Occupancy	Educational		
3	Building Comprised of	Ground + 01 upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/SZ/2017/1359 dated 13/09/2017		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	10/12/2020		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Hamid Ali (Asstt. Teacher)		
10	Year of construction			
11	Applicant letter No.	Email dated 04/12/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements as per Circular dated 01/03/2011	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6 m ✓	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	NA
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	02 nos	01 staircase + 01 ramp ✓	MR
	➤ Basement floor	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	1.5 m / 0.75 m	1.25 m , ramp- 1.3 m ✓	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	1.5 m	1.5 m ✓	MR
	f) Door size	1 m	1 m ✓	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	30 ACPH	NA	N/A
	• Upper floors	12 ACPH	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	04 no's	04 no's ✓	MR
	• Types	ABC & CO ₂	DCP type	MR
	• ISI Marking	ISI marked	ISI marked	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	N/A	01 no ✓	N/A
	• Length of hose-reel hose.	N/A	30 m ✓	N/A
	• Nozzle Diameter	N/A	5 mm ✓	N/A
7	Automatic fire detection & alarming system			


- M/13 -

	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Directorate of Education circular no. F.16//Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011, FSC issued vide letter No. F.6/DFS/MS/School/SZ/2017/1359 dated 13/09/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


12/12/2020


Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (M.RD)

DO (SD)


14/12

DO (SD)

F. T. P. least



15/12

~~ADO~~ ADO (M.RD)

FT letter is put up for sign. please

DO (SD)




17/12/2020