

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F.6/DFS/MS/School/2020/SZ/ 548

Dated: 10 / 12 / 2020

FIRE SAFETY CERTIFICATE

Certified that Nigam Pratibha Vidyalaya located at Nehru Nagar, New Delhi-110065 comprised of **Ground and one upper floor** was granted FSC by this department vide letter No. F.6/DFS/MS/School/2016/SZ/664 dated 28/04/2016. The premises was re-inspected by officer concerned of this department on 08/12/2020 in the presence of Ms. Ragini Srivastava (Principal) of the school and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular, F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 and that the school building is fit for occupancy class "Educational", with effect from10/12/2020 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/12/2020 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service
o/c

Copy to: -

1. The Principal, Nigam Pratibha Vidyalaya, Nehru Nagar, New Delhi-110065
2. The Commissioner, SDMC, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Nigam Pratibha Vidyalaya, Nehru Nagar, New Delhi-110065		
2	Type of Occupancy	Educational		
3	Building Comprised of	Ground + 01 upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2016/SZ/664 dated 28/04/2016		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	08/12/2020		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Ms. Ragini Srivastava (Principal)		
10	Year of construction	2012		
11	Applicant letter No.	Email dated 05/10/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Directorate of Education circular	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m	Provided	MR
		4.5 m	Provided	MR
		N/A	N/A	NA
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	02 nos	Provided	MR
	➤ Basement floor	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	1.5 m or less & 0.75 m	1.70 & 1.35 mts	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	01	Provided (01)	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1.0 mtr	Provided (1.0 mtr)	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH	NA	N/A
		12 ACPH	N/A	N/A
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	08 no's	Provided	MR
		ABC type	Provided	MR
		ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	N/A	N/A	N/A
		30 m	N/A	N/A
		5 mm	N/A	N/A

7	Automatic fire detection & alarming system	Not required		
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provisions of Lifts.	Not Applicable		
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A

- N/A -

	<ul style="list-style-type: none"> • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	01 ABC type fire extinguisher is provided near elect. Panel.	MR

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. F.6/DFS/MS/School/2016/52/664 dated 28/04/2016, renewal under the Directorate of Education circular no. F.16//Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011 is recommended.

Accordingly DFA is put up for approval and signature please.

(Signature)

08/12/2020

Signature of the Inspecting Officer

Name : Avtar Singh

Designation: ADO (M.RD)

DO (SD)

(Signature)
09/12

DCFO(S2) F. f. please

(Signature)
9/12

A DO/MR

FT letter is put up for sign please

DCFO(S2)

(Signature)
13/12

(Signature)

10/12/2020

M.S. Cell