

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/ School/52/2020/561

Dated: 17/12/2020

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Bal Vidyalaya (ID-1720001) located at Delhi Cantt, New Delhi-110010, comprised of Ground Plus Two Upper Floors (Old Block) & Three New Block all are Ground & One Upper Floor only owned / occupied by Sarvodaya Bal Vidyalaya, have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education, Circular No. 3298-3398 dated 01/03/2011 / NBC (Part-IV) and verified by the officer concerned of Fire Service on 01.12.2020 in presence of Mr. Sudhanshu (Head of School) and that the building / premises is fit for occupancy class Educational (Group B) with effect from 17/12/2020 for a period of 3 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/12/2020 at New Delhi by.

  
**(ATUL GARG)**  
**DIRECTOR.**

Copy to :-

1. The Principal, Sarvodaya Bal Vidyalaya (ID-1720001) located at Delhi Cantt, New Delhi-110010.
2. The Director of Education, Old Secretariat, Civil Lines, New Delhi-110052.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
7. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. There shall not be more than 45 students in class rooms in any case.

## INSPECTION REPORT

1. Name & address of the building: **Sarvodaya Bal Vidyalaya (ID-1720001), Delhi Cantt, New Delhi-110010.**
2. Type of Occupancy : **Educational (Ground & 1<sup>st</sup> Floor only)**
3. Building Comprised of : **Ground Plus Two Upper Floors (Old Block), School management constructed three new block all are ground plus one upper floor.**
4. Type of Case : **Renewal (Addition / Alteration)**
5. Details of previous NOC : **F6/DFS/MS/School/2014/SZ/1470 dated 27/11/2014**  
(For Ground & Two Upper Floors)
6. Fire Safety directives Letter No. : **DOE Circular no. 3298-3398 dated 01.03.2011**
7. Date of inspection : **01/12/2020**
8. Name of the Inspecting Officer : **A.D.O. (S.J.)**
9. Name and designation of Officer  
from the building side : **Mr. Sudhanshu (Head of School)**
10. Year of Construction : **1939 & 2015**
11. Applicant's letter No. : **SBV/DC/2020/332 dated 10/11/2020**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dated 01/03/11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	9 m	MR
	• Gate width	4.5 m	Accessible	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 m	1.50 m & 1.35 m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.5m	1.5m	MR
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	19	21	M/R
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	M/R
	• IS marking	Required	Provided	M/R

	• Total numbers on each floor	4	4	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM x 2	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-1. Shortcomings issued by this department vide letter No. F6/DFS/MS/School /2018/SZ/3509 dated 13/08/2018 have complied.

2. General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route .....Clear.....
2. LPG cylinders in laboratories .....Nil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB .....  
Electric circuit .....
4. Electric meter board .....Not under the staircase.....
5. Basement use as per BBL 1983 .....NA.....
6. Emergency telephone no. board .....Displayed.....
7. Generator set .....Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
Name : A.K. Jaiswal  
Designation : A.D.O. (S.J.)

*[Handwritten Signature]*  
7/12/2020

*[Handwritten Signature]*  
DO/SJ

*[Handwritten Signature]*  
08/12

*[Handwritten Signature]*  
DeFO/SJ

*[Handwritten Signature]*  
10/12

