

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2020/SZ/ 574

Dated: 21/12/2020

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C Primary (CO ED) School, Hauz Khas Village**, New Delhi-110016, comprised of ground plus two upper floors owned/occupied by S.D.M.C Primary (CO ED) School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and verified by officer concern of this department on 10/12/2020 in the presence of Mrs. Meenu Gogana (Principal) of the school and that the premises is fit for occupancy class "**Educational, Group-B**" (School) with effect from 21/12/2020 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 21/12/2020 at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Principal, S.D.M.C Primary (CO ED) School, Hauz Khas Village, New Delhi-110016,
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/12

INSPECTION REPORT				
1	Name & Address of the Building	S.D.M.C Primary (CO ED) School, Hauz Khas Village, New Delhi -110016		
2	Type of Occupancy	Educational, Building Group-B		
3	Building Comprised of	Ground plus two upper floor		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	DOE Circular dated 01/03/2011		
7	Date of Inspection	10/12/2020		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Meenu Gogana (Principal)		
10	Year of construction	2011		
11	Applicant letter No.	Gmail ID Dated 30/10/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular 2011	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6mtr ✓	MR
	• Gate width	4.5 mtr	Direct Accessible ✓	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	One	Two	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50 m / 0.75 m	1.27 m & 1.19 mtr ✓	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	One	MR
	e) Width of corridor	-NA-	-NA-	MR
	f) Door size	1 mtr	1 mtr ✓	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	08Nos	09 Nos ✓	MR
	• Types	ABC / Co2	ABC Type	MR
	• ISI Marking	ISI mark	Provided ✓	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	one	one ✓	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mtr	5mtr	MR
7	Automatic fire detection & alarming system.			

N/14

	<ul style="list-style-type: none"> Flow switch panel. PA system panel. Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	One ABC type FE found provided near electrical panel board	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular dated 01/03/2011, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

Ru
19/12/20

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

so/sd
[Signature]

ling
11/12

DeFO (SD)
[Signature]

[Signature]
11/12

C.F.O.

[Signature]
10/12

[Signature]
15/12/20

[Signature]

As approved, F.T. letter is put up for your signature pl.

10/12
17/12/2020

