

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6 DFS/MS/School/2020/SZ/ 547

Dated: 10 / 12 / 2020

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C. Primary School No.1, Dr. Ambedkar Nagar, Sector-3, New Delhi-110062 (ID-1959127)** comprised of ground plus one upper floor was granted FSC by this department vide letter No. F.6/DFS/MS/School/2017/SZ/180 dated 09/02/2017. The said premises was re-inspected by officer concerned of this department on 22/09/2020 in presence of Mrs. Sheetal Gupta (PRT) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with circular No.F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" Group-B, with effect from 10 / 12 / 2020 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10 / 12 / 2020 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

ofc

Copy to: -

1. The Principal, S.D.M.C. Primary School No.1, Dr. Ambedkar Nagar, Sector-3, New Delhi-110062.
2. The Directorate of Education, Govt. of NCT of Delhi Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. Building Sanctioned authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	S.D.M.C. Primary School No.1, Dr. Ambedkar Nagar, Sector-3, New Delhi-110062 (ID-1959127)		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground Plus One Upper Floor Only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2017/SZ/180 dated 09/02/2017		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	22/09/2020		
8	Name of the Inspecting Officers	ADO Bhupender Prakash		
9	Name & Designation of Officers from the building side	Mrs. Sheetal Gupta (PRT)		
10	Year of construction	2006		
11	Applicant letter No.	E-mail Dated 06/08/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular dated 01/03/2011 Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible -N/A- -N/A- 	<ul style="list-style-type: none"> 6m ✓ 4m ✓ -N/A- 	<ul style="list-style-type: none"> MR -N/A- -N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors ➤ Basement floor 	<ul style="list-style-type: none"> Two -N/A- 	<ul style="list-style-type: none"> Two -N/A- 	<ul style="list-style-type: none"> MR -N/A-
	b) Width of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors. ➤ Basement floor 	<ul style="list-style-type: none"> 1.5 m / 0.75 m -N/A- 	<ul style="list-style-type: none"> 1.72 m & 1.75 m ✓ -N/A- 	<ul style="list-style-type: none"> MR -N/A-
	c) Protection of exits			
	<ul style="list-style-type: none"> ➤ Fire check door ➤ Pressurization 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	1 mtr	Provided ✓	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	<ul style="list-style-type: none"> -N/A- -N/A- -N/A- -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- -N/A- -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- -N/A- -N/A- -N/A-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	<ul style="list-style-type: none"> -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- Natural Ventilation ✓ 	<ul style="list-style-type: none"> -N/A- -N/A-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	<ul style="list-style-type: none"> 08 No 's ABC / Co2 ISI Marked 	<ul style="list-style-type: none"> 08 No 's ✓ ABC ✓ Provided ✓ 	<ul style="list-style-type: none"> MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	<ul style="list-style-type: none"> -N/A- -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- -N/A- 	<ul style="list-style-type: none"> -N/A- -N/A- -N/A-

Renewal :

S.D.M.C. Primary School No.1, Dr. Ambedkar Nagar, Sector-3, New Delhi-110062

7	Automatic fire detection & alarming system.			
	• Type of detectors	-N/A-	-N/A-	-N/A-
	• Location of Main Panel	-N/A-	-N/A-	-N/A-
	• Location of Repeater Panel	-N/A-	-N/A-	-N/A-
	• Alternate source of power	-N/A-	-N/A-	-N/A-
	• Hooter's location	-N/A-	-N/A-	-N/A-
8.	MOEFA / Siren	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement.	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
	• Sprinkler above false ceiling	-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-N/A-	-N/A-	-N/A-
	• Number of Hydrant per floor	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
12.	Yard Hydrants.			
	• Total number of hydrants.	-N/A-	-N/A-	-N/A-
	• Hose box.	-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	• Overhead tank capacity.	-N/A-	-N/A-	-N/A-
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-N/A-	-N/A-	-N/A-
	• Pressurization of lift lobby.	-N/A-	-N/A-	-N/A-
	• Communication in lift car.	-N/A-	-N/A-	-N/A-
	• Fireman's switch.	-N/A-	-N/A-	-N/A-
	• Lift signage.	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	-N/A-	-N/A-	-N/A-
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-


19	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-

20. **Special Fire Protection System for the Protection of special Risk, if any.** -N/A-

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the DOE Circular dated 01/03/2011, the FSC issued vide letter No F.6/DFS/MS/School/2017/SZ/180 dated 09/02/2017 renewal is recommended.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name : Bhupender Prakash
 Designation: ADO

Renewal: S.D.M.C. Primary School No.1, Dr. Ambedkar Nagar, Sector-3, New Delhi-110062

P. Spk about 2(b).

DO (SD)

*Dir
28/09*

ADP (RSP)

Sir, it is submitted that during inspection the width of staircases were measured and found as 1.72m & 1.75m and same have been mentioned in inspection report & at N/13.

Submitted please.

*DO (SD)
Dir (SZ)*

*Dir
30/9*

*Prakash
30/9/2020*

P.T.O