

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**


No.F.6 DFS/MS/School/2020/SZ/ 567

Dated: 18/12/2020

**FIRE SAFETY CERTIFICATE**

Certified that the **Raja Ram Mohan Ray Sarvodaya Kanya Vidyalaya, Hauz Rani, New Delhi, 110017** comprised of Pry Block (Ground plus One upper floor) & Secondary Block (Ground plus three upper floor) was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2017/SZ/398 Dt. 16/03/2017. The said premises was re-inspected by officer concerned of this department on 10/12/2020 in presence of Mrs. Sangita Khurana (Vice-Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 18/12/2020 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 18/12/2020 at New Delhi by

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Principal, Raja Ram Mohan Ray Sarvodaya Kanya Vidyalaya, Hauz Rani, New Delhi, 110017
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

M/12

INSPECTION REPORT				
1	Name & Address of the Building	Raja Ram Mohan Ray Sarvodaya Kanya Vidyalaya, Hauz Rani, New Delhi-110017		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Pry School- Ground plus one upper floors Sec. School- Ground + Three Upper Floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2017/SZ/398 Dt. 16/03/2017		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	10/12/2020		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Sangita Khurana (Vice-Principal)		
10	Year of construction	1993		
11	Applicant letter No.	RRMR/SK/HR/2020/947 Dated 24/08/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Required	6 mtr ✓	MR
	• Gate width	-NA-	6 m, 3 m & 3 m ✓	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	Pry block- 1 No Sec. Block -02 No's	Pry block- 1 No Sec. Block -02 No's ✓	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.50 m / 0.75 m	Pry block- 1.5 m Sec. Block -1.30 m each ✓	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	Provided in each block ✓	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1 mtr	1 mtr ✓	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	<b>Smoke Management system.</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5	<b>Fire Extinguishers.</b>			
	• Total numbers	20 no's	20 Nos ✓	MR
	• Types	ABC / co2	ABC & co2 Type	MR
	• ISI Marking	ISI mark	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	01 No's	Provided in sec. block	MR
	• Length of hose-reel hose.	30 m	30 m ✓	MR
	• Nozzle Diameter	5 mm	5 mm ✓	MR





N/114

	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2017/SZ/398 Dt. 16/03/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Signature*  
10/12/2020

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

*Signature*  
11/12

*Signature*  
11/12

*Signature*  
11/12

*Signature*  
11/12

*Signature*  
11/12

*Signature*  
11/12

As approved, F-1. Letter is put up for your signature pl.

*Signature*  
16/12/2020

*Signature*  
11/12

*Signature*  
11/12

*Signature*  
11/12