

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F6/DFS/MS/2020/WZ/ EH/188

Dated : 23/12/2020

FIRE SAFETY CERTIFICATE

Certified that the **KFC Restaurant (M/s Sapphire Food India Pvt. Ltd), Fun City Mall at Prashant Vihar, Rohini Sector-14, Delhi-85**, is running at in a mall ground floor comprised of building **Basement + Ground + 4 upper floors**, was inspected by the officer concerned of this department on 24.11.2020 in the presence of **Mr. Madhur Sharma (Legal)** and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and that the premise is fit for occupancy **Group D "Assembly"(Eating House)** for **G-12 & G-14, ground floor only** with effect from 23/12/2020 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/12/2020 at New Delhi by

(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to:-

1. The Dy. Health Officer, North MCD, Sec-5, Rohini Zone, Delhi-110085.
2. Mr. Madhur Sharma (Legal), KFC Restaurant (M/s Sapphire Food India Pvt. Ltd), Fun City Mall at Prashant Vihar, Rohini Sector-14, Delhi-85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/>

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

INSPECTION REPORT

1. Name & address of the building : KFC Restaurant (M/s Sapphire Food India Pvt. Ltd), G-12 & G-14, Ground floor, Fun City Mall at Prashant Vihar, Rohini Sector-14, Delhi-85.
2. Type of Occupancy : Group D Assembly Building (Eating House)
3. Type of Case : New Case (**Restaurant is running at G-12 & G-14**) at Gr. floor
4. Details of Previous NOC : NA
5. Fire Safety directives letter No :
6. Date of inspection : 24.11.2019
7. Name of Inspecting Officer : A.K. Sharma
8. Name and designation of officers
From the building side : Mr. Madhur Sharma (Legal)
9. Year of Construction : 2013
10. Applicant's letter No. : Online application no.2020101307667 dated 13.10.2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building [Fun City Mall Prashant Vihar issued FSC vide letter No.F.6/DFS/MS/2019/WZ/911 dated 29.04.2019]			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restaurant within Mall	As Above	MR
2.	Number, Width, Type & Arrangement of Exits [Provided & Maintained by Mall management]			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
	d. No. of continuous staircases to terrace	Restaurant within Mall	As Above	NA
	e. Width of Corridor	Restaurant within Mall	As Above	NA
	f. Door Size	2.0 & 1.50 mtr	2.0 & 1.5 mtr	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
		Restaurant within Mall	As Above	NA
4.	Smoke Management System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH	NA	NA
		12 ACPH	Natural Ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	5 No's	5Nos	MR
		ABC/CO ₂ /W.CO ₂	5/-/No's	MR
		ISI marked	Provided	MR
6.	First-Aid Hose Reels [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One (Near to Restaurant)	As Above	MR
		30 m	As Above	MR
		5 mm	As Above	MR
7.	Automatic fire detection and alarming system [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel 	Required	Provided	MR
		NA	As Above	NA

	<ul style="list-style-type: none"> • Alternate source of power • Hooters' Location 	NA	As Above	NA
			As Above	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	As Above	NA
10.	Automatic Sprinkler System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Basement 	NA	As Above	NA
	<ul style="list-style-type: none"> • Ground Floor 	NA	As Above	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	As Above	NA
11.	Internal Hydrants [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100mm	As Above	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	One (near to Restaurant)	As Above	MR
	<ul style="list-style-type: none"> • Hose Box 	One (near to Restaurant)	As Above	MR
12.	Yard Hydrants [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13.	Pumping Arrangements [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		[Provided & Maintained by Mall management]		
		NA	As Above	MR
		NA	As Above	MR
		Required	As Above	MR
		Required	As Above	MR
14.	Captive Water Storage for firefighting [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
		NA	As Above	NA
		NA	As Above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication In lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17.	Standby power supply	Required	As Above	MR
18.	Refuge Area. [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> ➤ Total Area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA
19.	Fire Control Room [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Detector System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA

N-5

	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked at random and found in working competition.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Ajay
12/12/20

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (N/W)

Ajay
11/12/2020

Dy Cfo (W2)

[Signature]
11/12/2020

Cfo

Ajay
15/12



[Signature]

DD/NW PLS Spcl.

Spoken on 23/12/2020.

F.T. letter is put up for sign. pt.

Ajay
23/12/2020

Director
[Signature]
23/12/20