

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001


No. F.6/DFS/MS/School/2020/NDZ/ 559

Dated: 17/12/2020

FIRE SAFETY CERTIFICATE


Certified that Greenway International School at A- Block, Vivek Vihar, Phase – 1, Delhi-110095 comprised of basement, ground plus one upper floor owned/occupied by that Greenway International School was issued FSC vide letter No. F6/DFS/MS/School/2016/NDZ/1493 dated 10/10/2016. The School building have complied with the fire prevention and fire safety requirements in accordance with the circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officers concerned of this department on dated 04/12/2020 in the presence of Ms. Kalpana Devi, Principal of the school and found that the school building is fit for occupancy class “B” ‘Educational Building’ for basement, ground plus one floor with effect from 17/12/2020 for a period of **three** years, in accordance and further subject with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf..

Issued on 17/12/2020 at New Delhi by


16/12/2020
(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,
The Principal,
Greenway International School,
A- Block, Vivek Vihar, Phase – 1,
Delhi-110095

Copy:-
The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-110092


16/12

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT


10. Name & address of the building : Greenway International School ,
A-Block, Vivek Vihar, Phase-1, Delhi-110095
11. Building is comprised of : Basement, Ground plus one upper floors only
12. Type of Occupancy : Educational
13. Type of Case : Renewal
14. Details of Previous NOC letter : F6/DFS/MS/School/2016/NDZ/1493
dt-10/10/2016
15. Fire Safety direction letter No : F16/Estate/CC/Fire Safety/2011/3298 to
3398 dt-01/03/11
16. Date of Inspection : 08/12/2020
17. Name of the Inspecting officers : ADO Nagender Singh
18. Name and designation of Officer
from the building side : Ms. Kalpana Devi, Principal
10. Year of Construction : 2002
11. Applicant's Email ID : hs858805@gmail.com dt- 24/11/2020


Sr. No	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	06m	06m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	01 no.	02 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	B. Width of Staircases			
	• Upper Floor	1.50m	1.45m & 1.80m	MR
	• Basement	1.25m & 0.75m	1.30m & 0.93m	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	1.50m	1.50m	MR
	f. Door Size	01m	01m	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	30 a/c per hour	Provided	MR
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	08 nos.	08 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-aid-Hose Reels.			
	Total numbers on each floor	01 no.	provided	MR
	• Length of hose reel hose	30m	provided	MR
	• Nozzle diameter	05 mm	provided	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Requirement	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 Lpm.	provided	MR
	➤ Head of the Pump	40 M	provided	MR
	➤ Power supply	Required	provided	MR
	➤ Auto Starting of pump	Required	provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety required under the circular No- F16/Estate/CC/Fire Safety/2011/3298 to 3398 dt-01/03/11, it is recommended to renew Fire Safety Certificate under rule 37 of the Delhi fire Service Rules 2010.


(Nagender Singh)
Asstt. Divisional Officer
(Shahdara)


~~DO(ED)~~ 
10/12

~~Dy. CFO/NDZ~~


14/12/2020

~~ADDO (Shahdara)~~

FT submitted please


16/12

~~Dy CFO (NDZ)~~


16/12/2020

M.S.Cell