

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2020/585

Dated: 24/12/2020

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya, GG-III, Vikas Puri, SDMC ,West Zone, Delhi-110018, Comprised of ground plus one upper floor owned/occupied by Nigam Pratibha Vidyalaya was issued FSC vide letter no. F6/DFS/MS/School/2017/SZ/1767 dated 08/12/17. The school building was inspected by the officer concerned of this department on dated 11/12/2020 in the presence of Principal .The school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 issued by Directorate of Education, Govt.of NCT of Delhi, and found that the building is fit for occupancy class B 'Educational Building' with effect from 24/12/2020 for a period of three years, subject to conditions printed overleaf.

Issued on.....24/12/2020.....at New Delhi by


(Sunil Chawdhary)
Dy.Chief Fire Officer

9/12/20

To,

The Principal,
Nigam Pratibha Vidyalaya,
GG-III, Vikas Puri, SDMC ,
West Zone, Delhi-110018

Copy to:-

Deputy Director (Education) SDMC, 23rd floor,
Civic Centre , Minto Road, New Delhi.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Nigam Pratibha Vidyalaya, GG-III, Vikas Puri, SDMC, West Zone, Delhi-110018
 2. Building is comprised of : **Ground plus one upper floor**
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : F.6/DFS/MS/school/2017/SZ/1767 Dt.- 08/12/2017
 6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011
 7. Date of Inspection : 11/12/2020
 8. Name of the Inspecting Officers: : ADO R.K. YADAV
 9. Name of the designation of Officer
 from the building side : Principal
 10. Year of Construction : 1983, 2011
 11. Applicant's letter No : Nil Dated -04/12/2020

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	DOE CIR. Dated 1.3.2011	Provided at Site	Remarks MR/NMR	
1	Access to building				
	Road width	6 mtrs.	09 mtrs.	MR	
	Gate width	N/A	Direct accessible from road	MR	
	Width of internal road	N.A.	N.A.	N.A.	
2	Number, Width, Type and Arrangement of Exits				
	a. Number of Staircases				
		Upper Floor	3 nos.	3 nos.	MR
		Basement	N.A.	N.A.	N.A.
	B. Width of Staircases				
		Upper Floor	1.5 m	1.5 m, 1.50 m, & 1.28 mtrs	MR being old case
		Basement	N.A.	N.A.	N.A.
	c. Protection of exits				
		Fire check door	N.A.	N.A.	N.A.
		Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	2 nos.	2 nos.	MR	
	g. Width of Corridor	1.5	2 m	MR	
h. Door Size	1 m	1.05 m Double doors in each class room	MR		
3	Compartmentation.				
	Fire check door	N.A.	N.A.	N.A.	
	Sealing of electrical shafts	N.A.	N.A.	N.A.	
	Fire rating of shaft door	N.A.	N.A.	N.A.	
	Water curtain	N.A.	N.A.	N.A.	
	Fire Dampers	N.A.	N.A.	N.A.	
4	Smoke Management System.				
	Basement	N.A.	N.A.	N.A.	
	Upper floor	N.A.	N.A.	N.A.	

M/29

5.	Fire Extinguisher			
	Total numbers	05 Nos.	05 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

26

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	N.A.	N.A.	N.A.
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as per rules. The FSC was issued vide letter no. F6/DFS/MS/School/2017/SZ/1767 dated 08/12/2017 renewal under the circular no. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 is recommended.

Signature of the Inspecting Officer

Name R K YADAV

Designation ADO (JKP)

DO (South West)

Dy Cfo (SZ)

ADG/BJP

F. F. /> Seal

17/12/2020

R K YADAV
16/12/2020