

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6 DFS/MS/School/2020/SZ/ 587

Dated: 30/12/2020

FIRE SAFETY CERTIFICATE

Certified that **Olive Anthony Block** at the **Frank Anthony Public School** located at **Lajpat Nagar-IV, New Delhi-110024** comprised of **Junior Block** (Ground + 2 upper floors), **Middle Block** (LG floor, UG floor + 2 upper floors), **Senior Block** (Ground + 2 upper floors), **Admin Block** (Ground + 2 upper floors) was granted Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2017/SZ/1427 dated 27/09/2017. The premises was re-inspected by officer concerned by this department on 28/12/2020 in the presence of Mr. Rajesh Thakur (Security Officer) of the school and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rule 2010 and that the school building is fit for occupancy class "**Educational Building**" Group-B, as above with effect from ..... 30/12/2020 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/12/2020 at New Delhi by

(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

dc Az

Copy to: -

1. The Principal, the Frank Anthony Public School, Lajpat Nagar-IV, New Delhi-110024.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule, 2010. The form is available on [www.dfs.delhigovt.inc.in](http://www.dfs.delhigovt.inc.in).
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1	Name & Address of the Building	The Frank Anthony Public School, located at Lajpat Nagar-IV, New Delhi-110024.		
2	Type of Occupancy	Educational Building (School) "Group B"		
3	Building Comprised of	<b>Junior Block - Ground + 2 upper floors</b> <b>Middle Block- Lower Gd, Upper ground + 2 upper floors</b> <b>Senior Block - Ground + 2 upper floors</b> <b>Admin Block- Ground + 2 upper floors</b>		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2017/SZ/1427 dated 27/09/2017		
6	Fire Safety Directives Letter No	DOE Circular no. 262-362 dated 17/01/2005		
7	Date of Inspection	28/12/2020		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Rajesh Thakur (Security Officer)		
10	Year of construction	2006-07		
11	Applicant letter No.	Email dated 01/12/2020.		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC Requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	Required	6 m	MR
	• Gate width	Required	4.5 m	MR
	• Width of internal road	-N/A-	-N/A-	-N/A-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors	Required	Jr. Block-3, Mid. Block-2, Sr. Block- 4, & Admin Block- 4 nos	MR
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	Required	Jr. Block: 1.10 (2) & 1.50 m, Mid. Block: 1.50 & 1.30 m Sr. Block: 1.50 (04 nos) Admin Block- 1.50 m (4nos)	MR
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	<b>d) No. of continuous staircase to terrace</b>	Required	Jr. bk- 1, Mid bk- 1, Sr. bk- 1 Admin bk- 2 nos	MR
	<b>e) Width of corridor</b>	Required	1.50 m	MR
	<b>f) Door size</b>	1 m	1 m	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-N/A-	-N/A-
	• Upper floors	12 ACPH	-N/A-	-N/A-
<b>5.</b>	<b>Fire Extinguishers.</b>			



	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	ABC / CO <sub>2</sub>	ABC- 12, DCP- 08	MR
		ISI Marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>		<i>Az</i>	
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	1 & 2 nos	1802 nos provided	MR
	<ul style="list-style-type: none"> <li>Length of hose-reel hose.</li> </ul>	30 m	30 m	MR
	<ul style="list-style-type: none"> <li>Nozzle Diameter</li> </ul>	5 mm	5 mm	MR
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	-N/A-	-N/A-	-N/A-
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	-N/A-	-N/A-	-N/A-
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	-N/A-	-N/A-	-N/A-
<b>11.</b>	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser / Down-comer</li> </ul>	Required	100 mm	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	Required	Two	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	Required	Two	MR
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	-N/A-	-N/A-	-N/A-
<b>13</b>	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	Discharge of main pump.	-N/A-	900 LPM	-N/A-
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	-N/A-	50 m	-N/A-
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	-N/A-	One	-N/A-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual stopping.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40 m	40 m	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	-N/A-	-N/A-	-N/A-
<b>14.</b>	<b>Captive water storage for firefighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	25,000 ltrs	25,000 ltrs	MR
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	10,000 ltrs	50,000 ltrs	MR
		Required	Provided	MR
<b>15</b>	<b>Exit Signage</b>			

	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> <li>• Pressurization of lift lobby.</li> <li>• Communication in lift car.</li> <li>• Fireman's switch.</li> <li>• Lift signage.</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
17	<b>Standby Power Supply</b>			
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
19.	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel.</li> <li>• Flow Switch Panel.</li> <li>• PA system Panel.</li> <li>• Battery backup</li> <li>• Building floor plan</li> </ul>	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Required	ABC type fire extinguishers provided near elect panel	MR

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No F.6/DFS/MS/School/2017/SZ/1427 dated 27/09/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*(Signature)*  
28/12/2020

Signature of the Inspecting Officer  
Name : Avtar Singh  
Designation: ADO (M.RD)

DO (SD) on c/leave

DCFO (S2)

AD (M/R)

DCFO (S2)

*F.T. please*

*F.T. letter is put up for sign pl.*

*(Signature)*

*(Signature)*  
30/12/2020

*M.S. will*