

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2020/SZ/583

Dated: 24/12/2020

FIRE SAFETY CERTIFICATE

Certified that the Summer Field School, located at Kailash Colony, New Delhi-110048 comprised of basement, ground and 03 upper floors was issued FSC by this department vide letter No F6/DFS/MS/School/2018/SZ/1704 dated 20/07/2018. The premise was re-inspection by officer concerned by this department on 18/12/2020 in the presence of Mr. Inder Dev Gupta and observed that there is addition/alteration at each floor level in the existing school building. Now the school building is comprised of basement, ground and 03 upper floors and two small rooms at terrace level, have complied with the fire prevention and fire safety requirements in accordance with rules 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Educational, Group-B" (School) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 24/12/2020 at New Delhi by


(Atul Garg)
Director
ek

Copy to: -

1. The Principal, Summer Field School, located at Kailash Colony, New Delhi-110048
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Summer Field School, Kailash Colony, New Delhi 110048		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Basement + Ground +03 Floors + Two Small Store Rooms at Terrace.		
4	Type of Case	Addition Alteration		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/1704 Dt. 20/07/2018		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/92/715 Dated 06/04/1992		
7	Date of Inspection	18-12-2020		
8	Name of the Inspecting Officers	Dy. CFO (SZ) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Inder Dev Gupta		
10	Year of construction	1993 & 2020		
11	Applicant letter No.	Outdoor diary no 9799 Dated 11/12/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC/BBL requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	Required	4 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 No's	07 Nos	MR
	➤ Basement floor.	02 No's	02 Nos	MR
	b) Width of Staircase			
	➤ Upper floors	1.5 m	1.35, & 1.50 x 2	MR
	➤ Basement floor	1.5 m	1.50 x 2	MR
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	One	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	12 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	30 Nos	MR
	• Types	ABC	ABC Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Two	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection & alarming system.			

	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view the substantial satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

Signature of Inspecting Officer
 Name:- Sh. Sunil Chawdhary

Designation:- Dy CFSO

Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Design: ADO (BCP)

Dops - on leave

C.F.O. on duty

Signature
 22/12

Director
 Signature
 22/12/20
 FT PLS

Director

F.t. is put up for signature, please.

Director
 Signature
 23/12

Signature
 23/12