

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**


No. F6/DFS/MS/WZ/2020/ 07

Dated: 04/01/2021

FIRE SAFETY CERTIFICATE

Certified that the National Institute of Disaster Management (NIDM), Plot No.15, Block-B,, Pocket-3, Sector-29, Rohini, New Delhi comprised of Seven Blocks (1 Admin + 06 Residential) owned/ occupied by National Institute of Disaster Management (NIDM). The Admin block & Hostel-1 block Comprised of building (G+4) have complied with the fire prevention and fire safety accordance with rule 33 of the Delhi Fire Service rule 2010 and verified by the officer concerned of Delhi Fire Service on 11.12.2020 in the presence of **Sh. Mohinder Kumar AGM(ENGG)** and that the premises is fit for occupancy **Business & Residential** with effect from 04/01/2021 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed as below.

Issued on 04/01/2021 at New Delhi by


(Atul Garg)

DIRECTOR

Ph; 011-23414000



Copy to:

1. Sh. Mohinder Kumar AGM (ENGG). National Institute of Disaster Management (NIDM), Plot No.15, Block-B,, Pocket-3, Sector-29, Rohini, New Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director on Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on [http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Ru](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)
[les/ http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

INSPECTION REPORT

1. Name & address of the building : National Institute of Disaster Management (NIDM), Plot No.15, Block-B, Pocket-3, Sector-29, Rohini, New Delhi.
2. Type of Occupancy : Business & Residential (Hostel)
3. Type of Case : New Case **(G/S+4 upper floors)**
4. Details of Previous NOC : Nil
5. Fire Safety directives letter No : F.6DFS/MS/BP/2016/193 Dated 17.08.2016
6. Date of inspection : 11.12.2020
7. Name of Inspecting Officer : DO (NW) D.B. Mukherjee & ADO Rohini A.K.Sharma
8. Name and designation of officers
From the building side : Sh. Mohinder Kumar AGM(ENGG)
9. Year of Construction : 2016
10. Applicant's letter No. : Online mail dated 04.10.2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	18m 06m 06	80m 06m Proposed	MR MR MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 N/A	03 & 02 N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.5m N/A	2.15, 1.65 & 1.35mtr N/A	MR N/A
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	<ul style="list-style-type: none"> • Pressurization 	Required	Provided	MR
	d. No. of continuous staircases to terrace	All	All	MR
	e. Width of Corridor	2, 1.5 & 1.35m	2.4m & 1.5m	MR
	f. Door Size	1.5m & 1.35m	2.0m & 1.5m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types 	20 ABC/Co2	25 ABC, Co2, Water Co2	MR MR

	<ul style="list-style-type: none"> IS marking 	ISI Marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	02 + 01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground & Upper Floors 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	100mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	06	06	MR
	<ul style="list-style-type: none"> Hose Box 	06	06	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	05	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	05	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	2280lpm	2280lpm	MR
	<ul style="list-style-type: none"> ➤ Head of Main pump 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	02	02	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 			
	<ul style="list-style-type: none"> ➤ Jockey pump head 	180lpm	280lpm	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	70m	70m	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	2850lpm	2850lpm	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	80m	80m	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Direct	Provided	MR
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900 & 450lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	75000ltr	100000ltr	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR

N-4

	• Overhead Tank capacity	10000, 25,000 & 5000 ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	Provided	MR

The fire protection systems provided in the building were tested, checked at random and found in working condition.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
 Name (D.B. Mukherjee)
 Designation DO (NW)

Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)



Handwritten signatures and dates: 23/12/2020, 20/12/20, 29/12/20, 29/12/20.

Handwritten notes and dates: 29/12, 24/12/2020, 1- HPLC, 2- Recm my kmul be statul why it is de cmul com pler.