

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6 DFS/MS/School/2020/SZ/ 07

Dated: 05/01/2020

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya, (ID- 1923061)** located at **Sultanpur, New Delhi, 110030** comprised of ground plus One upper floors was granted Fire Safety Certificate by this department vide letter No F6/DFS/MS/School/2017/SZ/1568 Dt. 03/11/2017. The said premises was re-inspected by officer concerned of this department on 22/12/2020 in presence of Mrs. Kanta Devi (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 05/01/2020 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 05/01/2020 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya, (ID- 1923061) Sultanpur, New Delhi, 110030
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

| | | | | |
|--------------|---|--|--|-----------------------|
| 1 | Name & Address of the Building | Sarvodaya Kanya Vidyalaya, Sultanpur, New Delhi-110030 (ID -1923061) | | |
| 2 | Type of Occupancy | Educational, Group-B (School) | | |
| 3 | Building Comprised of | 02 Blocks GF only & 03 Blocks - ground + one upper floor | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DFS/MS/School/2017/SZ/1568 Dt. 03/11/2017 | | |
| 6 | Fire Safety Directives Letter No | F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 | | |
| 7 | Date of Inspection | 22-12-2020 | | |
| 8 | Name of the Inspecting Officers | Sh. Rajesh Kumar ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Mrs. Kanta Devi (Principal) | | |
| 10 | Year of construction | 1995 & 2014 | | |
| 11 | Applicant letter No. | Gmail ID Dated 20/09/2020 | | |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC requirements | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | Required | 6 mtr ✓ | MR |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | <ul style="list-style-type: none"> ➤ Upper floors. ➤ Basement floor. | Old blk- 2 No's New blk- 1+1+2 No's | Old blk- 2 No's New blk- 1+1+2 No's ✓ | MR |
| | | -NA- | -NA- | -NA- |
| | b) Width of Staircase | | | |
| | <ul style="list-style-type: none"> ➤ Upper floors ➤ Basement floor | 1.5 m / 0.75 m | Old blk- 1.30 m each New blk - 1.5 m each ✓ | MR |
| | | -NA- | -NA- | -NA- |
| | c) Protection of exits | | | |
| | <ul style="list-style-type: none"> ➤ Fire check door ➤ Pressurization | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | One in each block | One ✓ | MR |
| | e) Width of corridor | -NA- | -NA- | -NA- |
| | f) Door size | 1 mtr | 1 mtr ✓ | MR |
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | <ul style="list-style-type: none"> • Basement • Upper floors | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 5. | Fire Extinguishers. | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • ISI Marking | 20no's Required | 25 Nos ✓ | MR |
| | | ABC | ABC Type | MR |
| | | ISI mark | Provided ✓ | MR |
| 6. | First Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 7 | Automatic fire detection & alarming system. | | | |
| | <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2017/SZ/1568 Dt. 03/11/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

My
22/12/2017

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

D/S

22/12

D/S

F. t. please

~~A DO BCP~~

As approved, F.I. letter is put up for your signature pl.

My
22/12/2017

D/S

M.S. cell