

2179

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2020/ 04

Dated: 05/01/2021

FIRE SAFETY CERTIFICATE

Certified that **Vidya Bharti School, Sector-15, Rohini, Delhi-110085**, comprised of **Ground + Three Upper floors** owned/occupied by **Vidya Bharti School** was issued fire safety certificate by this department vide letter no **F-6/DFS/MS/School/WZ/2018/347 dated 28.02.2018**. The premises was re-inspected by the officer concerned of this department on **15.12.2020** in the presence of **Smt. Sovanika Pal (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules 2010, and the building/ premise is fit for occupancy under **Educational Class** with effect from **05/01/2020** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on **05/01/2021** at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

Copy to:

1. The Principal, Vidya Bharti School, Sector-15, Rohini, Delhi-110085.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

1. Name & address of the building : Vidyapeeth Educational (Ground + 3 upper floors)
2. Type of Occupancy : Educational (Ground + 3 upper floors)
3. Type of Case : Renewal
4. Details of Previous NOC : F-6/DFS/MS/School/WZ/2018/347 dated 28.02.2018
5. Fire Safety directives letter No : Director of Education 17.01.2005
6. Date of inspection : 15.12.2020
7. Name of Inspecting Officer : A.K.Sharma ADO (Rohini)
8. Name and designation of officers
From the building side : Smt. Sovanika Pal (Principal)
9. Year of Construction : 1992-93
10. Applicant's letter No. : VBS/DFS/12758/20 dated 02.09.2020,

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6m	6m	MR
	• Gate width	5m	5m	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.5m	1.5m each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	04	04	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	18	18	MR
	• Types	ABC/Co2/Wco2	8ABC, 7Wco2 & 3Co2	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors		N/A	N/A
	• Location of Main Panel		N/A	N/A
	• Location of Repeater Panel		N/A	N/A
	• Alternate source of power		N/A	N/A
	• Hooters' Location		N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
		N/A	N/A	N/A

	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	4"	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	03	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	03	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	450lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of Main pump 	40m	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	180lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	40m	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of the pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Power Supply 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	25000ltr	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Overhead Tank capacity 	5000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Battery backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFS/MS/School/WZ/2018/347 dated 28.12.2018. Renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended

Signature of the Inspecting Officer
Name :- A.K.Sharma
Designation:- ADO/Rohini

DO (NW)

Dy cfo (w2)

ADO/Rohini

FF letter is put up for kind perusal
and signature please.

Dcfo(w2)

ms/leg