

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


No. F.6/DFS/MS/EH/SZ/2020/09

Dated: 07/01/2020

**FIRE SAFETY CERTIFICATE**

Certified that M/s ITP Laidback Café (A Unit of Jhakaas Restaurants Pvt. Ltd) running at ground, first, second and third floor of M-51, M Block Market, Greater Kailash -II, New Delhi 110048 comprised of basement (not part of restt.) ground and three upper floor was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/EH/2017/SZ/1476 dated 10/10/2017. The restaurant premise was re-inspected by the officer concerned of this department on 29/12/2020 in the presence of Sh. Dhiraj Arora of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class D "Assembly Building" Restaurant as above with effect from 07/01/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07 / 01 /2020 at New Delhi by

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi.
2. ITP Laidback Café (A Unit of Jhakaas Restaurants Pvt. Ltd) running at ground, first, second and third floor of M-51, M Block Market, Greater Kailash -II, New Delhi 110048

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

		II, New Delhi 110048 (A Unit of Jhakaas Restt. Pvt. Ltd)		
2	Type of Occupancy	Group-D Assembly Building.		
3	Building Comprised of	Basement, Ground + Three upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2017/SZ/1476 dated 10/10/2017		
6	Fire Safety Directives Letter No	Cir.No.F.6/DFS/EH/MS/ 2005/718 dated 04/04/2005		
7	Date of Inspection	29/12/2020		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Dhiraj Arora		
10	Year of construction	1999	Restt. at ground, 1 <sup>st</sup> 2 <sup>nd</sup> & 3 <sup>rd</sup> floor of the bldg.	
11	Applicant letter No.	Online No. 2020100707432 dated 01/12/2020		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Cir. No 718 dt 04/04/2005</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	Required	9m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 Nos	02 Nos	MR
	➤ Basement floor.	N/A	Not part of Restt.	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1 & 1.25 m	1 & 1.25 m	MR (old case)
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	Required	One	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	1 mtr	1 m (2 mtr)	MR (old case)
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
<b>5</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	10 Nos	10 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC-07 & CO <sub>2</sub> -03	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

Automatic fire detection & alarming system.				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Ground floor.</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	Required	100 mm	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	Required	One	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	Required	One	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	N/A	N/A	N/A
13	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	225 & 180 LPM	450 LPM x 2	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided	MR
14	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	5,000 Ltrs	10,000 ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location</li> </ul>	N/A	N/A	N/A

19	<b>Fire Control Room.</b>			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	N/A	N/A

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/2017/SZ/1476 dated 10/10/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*RK*  
29/12/2020

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Designation: ADO (BCP)

*D/S/D - on leave*

*D/CF/52 F, t. please.*

*~~ADO BCP~~*

*As approved, F.T. letter is put up for your signature @1*

*1/14*  
01/01/2020

*D/CF/52 5/1/2021*

*M.S. AD*