

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/ EH/52/2021/03

Dated: 01/01/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Limit Less Loop (A Unit of SVS Hospitality) located at Unit No-C-309, C-310, Third Floor, Ansal Plaza, Hudco Place, Khelgaon Marg, , Andrews Ganj, New Delhi-110049, comprised of two tier Basements, Ground, Mezzanine plus three upper floors, **but restaurant is at third floor only** owned / occupied by A Unit of SVS Hospitality, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 02/12/2020 in the presence of Mr. Vishal Prabhakar and found that the building / premises is fit for the occupancy class "Assembly" (Group-D) / Eating House with effect from 01/01/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/01/2021 **at New Delhi by.**


(ATUL GARG)
DIRECTOR.
OIC

Copy to :-

1. Addl. Commissioner, Licensing Unit, 1st Floor, Police Station, Defence Colony, New Delhi-110024.
2. M/s Limit Less Loop (A Unit of SVS Hospitality) located at Unit No-C-309, C-310, Third Floor, Ansal Plaza, Hudco Place, Khelgaon Marg, , Andrews Ganj, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Covered area of the restaurant is 337m² and as per NBC (Part-IV) the no. of occupants comes out to be Approx. 187 (337/1.8=187.22). Thus capacity of restaurant is 187 persons which is covered under DFS Act 2007, Rules 2010.

Subsequently inspection of Eating House is carried out as per NBC (Part-IV).

1. Name & address of the building: **M/s Limit Less Loop (A Unit of SVS Hospitality) Unit No-C-309, C-310, Third Floor, Ansal Plaza, Hudco Place, Khelgaon Marg, , Andrews Ganj, New Delhi-110049.**
2. Type of Occupancy : **Assembly (Group-D) (Eating House) (Two tier basements, Ground Mezzanine plus three upper floors. But restaurant is at third floor only.**
3. Type of Case : **New**
4. Details of previous NOC: FSC issued to the Mall vide letter No. **F6/DFS/MS/Mixed/2020/SZ/359 dated 11/09/2020**
5. Fire Safety directives Letter No. : **Nil**
6. Date of inspection : **02/12/2020**
7. Name of the Inspecting Officer : **A.D.O. (S.J.)**
8. Name and designation of Officer from the building side : **Mr. Vishal Prabhakar**
9. Year of Construction : **1997-1999**
10. Applicant's letter : **MHA Id-2020102107914 dated 03/11/2020**

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	6 m	12 m		MR
	• Gate width	4.5m	5 m		MR
	• Width of internal road	6 m	6m		MR
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	2		2	NA
	• Basements	NA		NA	NA
	b. Width of staircases				
	• Upper floors	1.50m		Provided	MR
	• Basements	NA		NA	NA
	c. Protection of exits				
	• Fire check door	Required	Provided		MR
	• Pressurization	NA	NA		NA
	d. No of continuous staircase to terrace	Required	04Nos(One in A Block, One in B Block & Two in C Block)		MR (Old Case)
	e. Width Of Corridor	1.5m	Provided		MR
	f. Door Size	2.00m & 1.50m	2.00m & 1.70m		MR
3.	Compartmentation				
	• Fire check door	Required	Provided		MR
	• Sealing of electrical shafts	Required	Provided		MR
	• Fire Rating of shaft door	Required	Provided		MR
	• Water Curtain	NA	NA		NA
	• Fire Dampers	NA	NA		NA
4.	Smoke managements System				
	• Basements	30 a/c per hour	N/A		NA
	• Upper floors	12 a/c per hour	Exhaust Fans Provided		MR
5.	Fire Extinguishers				
	• Total numbers	6	6		M/R
	• Types	ABC, CO ₂ & WCO ₂	ABC, CO ₂ , Water CO ₂		M/R
	• ISI marking	Required	Provided		M/R

6.	• Total numbers on each floor	2	2 (Near restaurant)	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system (Fire Fighting System is common for entire mall building)			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System (Fire Fighting System is common for entire mall building)			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants (Fire Fighting System is common for entire mall building)			
	• Size of riser/down-comer	150mm	150mm	MR
	• Number of hydrants per floor	2 (Near restaurant)	2 (Near restaurant)	MR
	• Hose Box	2 (Near restaurant)	2 (Near restaurant)	MR
12.	Yard Hydrants (Fire Fighting System is common for entire mall building)			
	• Total number of hydrants	8	8	MR
	• Hose Box	8	8	MR
13.	Pumping Arrangements (Fire Fighting System is common for entire mall building)			
• Ground Level				
➤	Discharge of main pump	Required	4050 LPM Provided	MR
➤	Head of main pump	Required	90 M	MR
➤	Number of main pumps	Required	2nos.	MR
➤	Jockey pump out put	Required	450 LPM	MR
➤	Jockey pump head	Required	90m	MR
➤	Standby Pump out put	Required	8100 LPM Provided	MR
➤	Standby Pump Head	Required	90m	MR
➤	Auto Starting/Manual stopping	Required	Provided	MR
➤	Pump House Access	Required	Provided	MR
• Terrace level				
➤	Discharge of pump	NA	NA	NA
➤	Head of the pump	NA	NA	NA
➤	Power supply	NA	NA	NA
➤	Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting (Fire Fighting System is common for entire mall building)			
	• Underground tank capacity	4,50,000 ltr	4,50,000 ltr	NA
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room (Fire Fighting System is common for entire mall building)			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO ₂ & ABC Type Fire Extinguishers Provided near Electric Panel=MR		

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Received on
29/12/2020

DO (SD) on leave
Dcf/s2
29/12/2020

29/12
C.F.O. on leave

Director of M/V

31/12/2020
FIP/S
Ft. letter is put up

Appraisal
24/12/2020
Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : A.D.O. (S.J.)