

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6/DFS/MS/GH/2020/SZ/ 08

Dated: 07/01/2020

FIRE SAFETY CERTIFICATE

Certified that the Guest House Rockland Inn Situated at B- 208, Chittranjan Park, New Delhi 110019, comprised of basement, ground plus three upper floors having total 22 guest room was already been issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/GH/2018/SZ/201 dated 02/02/2018. The premise was re-inspected by the officer concerned of this department on 15/12/2020 in the presence of Mr. Deep Krishan (Gen. Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Residential, Group-A**" (Guest House) with effect from the date of issue 07/01/2020 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 07/01/2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Manager Rockland Inn Situated at B- 208, Chittranjan Park, New Delhi 110019,
2. The Addl. Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."
7. The provision's under clause 7.31 of UBBL-2016 shall be done in the building on or before 31/03/2021 in compliance to the notification dated 27/05/2019 an as approved and extended the deadline for compliance time limit by the Hon'ble Minister (UD) vide letter No F5 (189)/AD/ LB/2016/710-725 dated 17/12/2020

INSPECTION REPORT

1	Name & Address of the Building	M/s Rockland Inn located at B-208, Chittranjan Park, New Delhi-110019		
2	Type of Occupancy	Residential, "Group-A" (Guest House)		
3	Building Comprised of	Basement, Ground + 03 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/GH/2018/SZ/201 dated 02/02/2018		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	15/12/2020		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Deep Krishan (Gen. Manager)		
10	Year of construction	2002	Basement storage, GF (Rec. + 6 G/Room First Floor (06 Room) Second floor (06 Room) Third floor (04 Room)	
11	Applicant letter No.	Online ID No 2020083106524 dated 15/10/2020		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	06 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Required	02 Nos	MR
	➤ Basement floor.	Required	02 Nos	MR
	b) Width of Staircase			
	➤ Upper floors	0.90 mtr	0.90 m & 0.75 m	MR (old case)
	➤ Basement floor	0.90 mtr	0.95 m & 1.0 m	MR (old case)
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	1.16m (final exit)	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	-NA-	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	10 Nos	Provided	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR

	<ul style="list-style-type: none"> Nozzle Diameter 	5 mm	Provided	MR
7	Automatic fire detection & alarming system.	Circular date 17/12/2020 amendment / modification in (UBBL-2016 till 31/03/2021)		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors. Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		450 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	Required	27,000 ltr	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
		Required	15,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR

18	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The fire protection system provided in the premises were checked, tested at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/GH/2018/SZ/201 dated 02/02/2018, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Ru
29/12

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation: - ADO/BCP

DOBO - on Leave F.t. please
Dy CFS/S2

ADO/BCP

As approved, f.t. letter is put up for your signature pl.

1/14
5/11/2021

Dy CFS/S2
7/11/2021

on S. up