

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHTPLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/SZ/2021/ 28

Dated: 11/01/2021

FIRE SAFETY CERTIFICATE

Certified that the Banasthali Public School, G-Block, Plot No.-16, Vikaspuri, New Delhi-18, comprised of ground plus two upper floors owned/occupied by Banasthali Public School was granted FSC vide letter no. No. F.6/DFS/MS/School/2017/SZ/1694 dated 20/11/2017. The school building was re-inspected by the officer concerned of this department on 21/12/2020 in the presence of Smt. Anubha Goyal (Principal) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of Delhi Fire Rules 2010 that the building is fit for occupancy Group "B "Educational Building" with effect from 11/01/2021... for a period of **three** years, subject to conditions printed overleaf.
Issued on ...11/01/2021..... at New Delhi by

(Sunil Chawdhary)

Dy. Chief Fire Officer

To,

The Principal
Banasthali Public School,
G-Block, Plot No.-16, Vikaspuri, New Delhi-18.

Copy to:-

The Director of Education
GNCT of Delhi, Old secretariat
Delhi -54.

- Conditions -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry

INSPECTION REPORT

1. Name & address of the building : Banasthali Public School, G-Block, Plot No.-16, Vikaspuri, New Delhi-18
2. Building comprised of : ground plus two upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2017/SZ/1694 dated 20/11/17
6. Fire Safety directives letter No : N/A
7. Date of inspection : 21/12/2020
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Smt. Anubha Goyal (Principal)
10. Year of Construction : 2000
11. Applicant's letter No. : Nil dated 26/10/2020


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per previous FSC dt-20/11/2017	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	12 mtrs Directly accessible from road N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No.'s N/A	02 No.'s N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50 M & .75 M N/A	1.5 M, 1.5 M and 1.28 N/A	MR old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		1 no.	1no.	MR
		1.50 m	1.60 & 1.30 m	MR
	e. Width of Corridor			
		1 m	1.06 m	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	15 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR

First Aid Hose Reels				
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 no. 30 mtrs 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	100 mm Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM & 180 LPM 40 mtrs N/A N/A	N/A Provided Provided N/A N/A	N/A MR MR N/A N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 10,000 ltrs	1,00,000 ltrs N/A Provided N/A 40,000 ltrs	N/A N/A N/A N/A MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. No Lift			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 	N/A N/A	N/A N/A	N/A N/A


	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2017/SZ/1694 dated 20/11/2017 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of Inspecting Officer 4/1/2021
 Name:- R.K.Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)


06/01/2021
 Ft. please

A DO (S.W.)
 Ft. better as per up for sign. pl.
