

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/SZ/2020/ 17

Dated: 06/01/2021

FIRE SAFETY CERTIFICATE

Certified that the Chhotu Ram Memorial Adarsh Public School, Vill.-Kair, New Delhi-43, Comprised of ground floor, having total 09 rooms including class rooms, Library, sci. room, Comp. Room, Store & Office etc owned/occupied by Chhotu Ram Memorial Adarsh Public School, Was issued Fire Safety Certificate by this department vide letter No F6/DFS/MS/School/2017/SZ/422 dated 15/03/2018. The school building was inspected by the officer concerned of this department on dated 26/11/2020 in the presence of Sh.Hemant Kaushik (Manager) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and found that the building is fit for occupancy class B 'Educational Building' with effect from 06/01/2021 for a period of three years, subject to conditions printed overleaf.
Issued on.....06/01/2021.....at New Delhi by



(Sunil Chawdhary)
Dy.Chief Fire Officer



Copy to:-

- 1.The Principal
Chhotu Ram Memorial Adarsh Public School,
Village-Kair, New Delhi-110043.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/12

INSPECTION REPORT

1. Name & address of the building : Chhotu Ram Memorial Adarsh Public School, Vill.-Kair, New Delhi-43
2. Building is comprised of : **Ground Floor only (first floor removed)**
3. Type of Occupancy : Educational
4. Type of Case : Alteration
5. Details of Previous NOC : F.6/DFS/MS/school/2018/SZ/422 Dt.- 15/03/2018
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011
7. Date of Inspection : 26/11/2020
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer
from the building side : Mrs. Hemant kaushik (Manager)
10. Year of Construction : 2005
11. Applicant's letter No : CRMA/10/20 Dated -28/10/2020


S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33 as per DOE cir. dt. 01/03/2011	Requirement DOE cir. dt. 01/03/2011	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 mtrs.	12 mtrs.	MR
	Gate width	4.5 mtrs.	4.5 mtrs.	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	1 nos.	2nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	N.A.	N.A.	N.A.
	Upper Floor	1.5 m	1.0 & .76 m	MR
	Basement			
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door			
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
h. Door Size	1.5 m	2.1 m	MR	
	1 m	1.05 m (Double Door)	MR	
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural Ventilation Provided	MR

N/14




14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	N.A.	N.A.	N.A.
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

Previously NOC was issued vide letter no. F6/DFS/MS/School/2018/SZ/422 dated 15/03/2018 for ground & first floor but now it become ground floor only. The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education. It recommended issuing Fire Safety Certificate.


 Signature of the Inspecting Officer
 Name R K YADAV
 Designation ADO (Janakpuri)

DO (South-west)


 06/01/2021
 Dy CBO (S2) 
 RT letter is put up for signature pls

 07/01/2021