

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6/DFS/MS/EH/SZ/2021/12

Dated 12/01/2021

**FIRE SAFETY CERTIFICATE**

Certified that M/s Chilis Grill & Bar Restaurant (A Unit of Paramount Restaurants Pvt. Ltd) at Shop No- 161, Ground Floor, DLF Place, Saket, New Delhi, running at ground Floor of the building comprised of three tier basement, ground plus seven upper floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2017/SZ/495 dated 31/03/2017. The restaurant premise was re-inspected by the officer concerned of this department on 07/01/2021 in the presence of Sh.Vabhav of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class D "Assembly Building" Restaurant as above with effect from 12/01/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/01/2021 at New Delhi by



(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service



Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi.
2. M/s Chilis Grill & Bar Restaurant (A Unit of Paramount Restaurants Pvt. Ltd) at Shop No- 161, Ground Floor, DLF Place, Saket, Delhi.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	M/s Chilis Grill & Bar Restaurant at Shop No 161, Ground Floor, DLF Place, Saket, New Delhi -110070 (A Unit of Paramount Restaurants Pvt. Ltd)		
2	Type of Occupancy	Group-D Assembly Building. (Restaurant)		
3	Building Comprised of	03 tier Basements, Ground + 07 Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2017/SZ/495 dated 31/03/2017		
6	Fire Safety Directives Letter No	DLF Place Mall,- F.6/MS/DFS/BP/2005/2073 dated 04/10/2005 & F.6/MS/DFS/BP/2019/135 dated 01/04/2019		
7	Date of Inspection	07/01/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Vabav		
10	Year of construction	2005		
11	Applicant letter No.	Gmail dated 24/12/2020		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>	<b>( DLF Place Mall - F.6/DFS/MS/Mall/2019/SZ/1832 Dt. 23/09/2019)</b>		
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Restt. within DLF Promenade Mall	Provided by Mall N/A N/A	MR N/A N/A
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>	Provided & Maintained by DLF Place, Saket		
	➤ Upper floors.	Restt within Mall	As above	MR
	➤ Basement floor.	N/A	N/A	N/A
	<b>b) Width of Staircase</b>	Provided & Maintained by DLF Place, Saket		
	➤ Upper floors	Restt within Mall	As above	MR
	➤ Basement floor	N/A	N/A	N/A
	<b>c) Protection of exits</b>	Provided & Maintained by DLF Place, Saket		
	➤ Fire check door	Restt within Mall	As above	MR
	➤ Pressurization	Restt within Mall	As above	MR
	<b>d) No. of continuous staircase to terrace</b>	Restt within Mall	-NA-	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	02 required	2 m& 1.31 m	MR (old case)
<b>3</b>	<b>Compartmentation.</b>	Provided & Maintained by DLF Place, Saket		
	• Fire check door.	Restt within Mall	As above	MR
	• Sealing of electrical shafts.	Restt within Mall	As above	MR
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>	Provided & Maintained by DLF Place, Saket		
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
<b>5</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	08 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI Marking	Required	Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>	Provided & Maintained by DLF Place, Saket		
	• Total numbers on each floor.	One near Restt	As above	MR
	• Length of hose-reel hose.	30m	As above	MR
	• Nozzle Diameter	5mm	As above	MR
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>	(Provided & Maintained by DLF Place, Saket		
	• Type of detectors	Required	Smoke & heat	MR
	• Location of Main Panel	Required	As above	MR
	• Location of Repeater Panel	Required	As above	MR
	• Alternate source of power	Required	As above	MR
	• Hooter's location	Required	As above	MR
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR

9	<b>Public Address System</b>	N/A	As above	MR
10	<b>Automatic Sprinkler System</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	As above	MR
	<ul style="list-style-type: none"> <li>Ground floor.</li> </ul>	Required	As above	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	Required	As above	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	One near Restt	As above	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	One near Restt	As above	MR
12	<b>Yard Hydrants.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	N/A	As above	N/A
13	<b>Pumping arrangements.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>	<b>Common pumping arrangements for entire bldg</b>		
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	4500 LPM	4500 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	70m	70m	MR
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	02 Nos.	02 Nos.	MR
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	180 LPM	180 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	70m	70m	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	4500 LPM	2 X 4500 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	70m	70m	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	450 LPM	As above	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40 m	As above	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	As above	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	As above	MR
14	<b>Captive water storage for fire fighting.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	Required	3,70,000 Ltrs	MR
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	Required	30,000 Ltrs	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	N/A	As above	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room.</b>	Provided & Maintained by DLF Place, Saket		
	<ul style="list-style-type: none"> <li>Detector system panel.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>Flow switch panel.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>PA system panel.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>Battery backup.</li> </ul>	N/A	As above	N/A
	<ul style="list-style-type: none"> <li>Building floor plan.</li> </ul>	N/A	As above	N/A
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	As above	N/A

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2017/SZ/495 dated 31/03/2017, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

11/01/2021

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Designation: ADO (BCP)

Dy CFSO - on Leave

Dy CFSO F.T. please

Sh

ADO BCP

As approved, F.T. letter is put up for your signature pl.

11/01/2021

Dy CFSO

Sh  
11/11

M.S. Cell