

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/EH/2020/SZ/10

Dated: 07/01/2021

FIRE SAFETY CERTIFICATE

Certified that the **M/s KFC Restaurant (A unit of sapphire foods)**, UGF, C-1/133, Lal Sai Mandir Marg, Janakpuri, New Delhi-110058, building is comprised of basement, stilt, upper ground floor plus two upper floors but the restaurant is running at upper ground floor only, was issued FSC by this department vide letter F6/DFS/MS/EH/2018/SZ/1093 dated 16/05/2018 owned/occupied by M/s KFC Restaurant (A unit of sapphire foods) was re-inspected by the officers concerned of this department on 21/12/2020 in the presence of Sh. Md. Jakir (Restaurant Manager) and found that Management of M/s KFC Restaurant (A unit of sapphire foods) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Upper Ground Floor Only**) is fit for occupancy class Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years, subject to the conditions printed overleaf.

Issued on.....07/01/2021..... at New Delhi.

(Sunil Chawdhary)
Dy.Chief Fire Officer

Copy to:-

1. The Manager,
M/s KFC Restaurant (A unit of sapphire foods),
UGF, C-1/133, Lal Sai Mandir Marg, Janakpuri, New Delhi-110058
2. The Dy. Health Officer,
S.D.M.C, Public Health Department, West Zone,
Vishal Enclave, Rajouri Garden, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s KFC Restaurant (A unit of sapphire foods), UGF, C-1/133, Lal Sai Mandir Marg, Janakpuri, New Delhi-110058
2. Building comprised of : B, stilt, upper gr.+2 upper floors but restaurant at upper ground only
3. Type of Occupancy : Group D (Assembly Building)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/EH/2018/SZ/1093 dated 16/05/2018
6. Fire Safety directives letter No : N/A
7. Date of inspection : 21/12/2020
8. Name of Inspecting Officers : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Md.Jabir (Restaurant Manager)
10. Year of Construction : 2009
11. Applicant's letter No. : ID No.2020120808890 dated 08/12/20

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mtrs 4.5 mtrs N/A	12 mtrs 5.3 mtrs N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 no.'s	02 no.'s (stilt to upper GF)	MR (restaurant at UGF only)
	• Basements	N/A	N/A	N/A
	b. Width of staircases	1.5 m	1.90 & .90 m	MR being old bldg.
	• Upper Floor	N/A	N/A	N/A
	• Basements			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	One	N/A
	e. Width of Corridor	N/A	Opening in hall	N/A
	f. Door Size	02 mtrs	2.0 & 1.20 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	04 No.'s	Provided	MR
	• Types	ABC/CO ₂	Provided	MR
	• ISI marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			(Restaurant is at UGF only)


N/13

	<ul style="list-style-type: none"> Total numbers on ground floor Length of hose reel hose Nozzle diameter 	One 30 mtrs 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat Required N/A Required Required	Provided UG Floor N/A Provided At exit	MR MR N/A MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System (Restaurant is at UGF only)			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A Required N/A	N/A Provided N/A	N/A MR N/A
11.	Internal Hydrants (Restaurant is at UGF only)			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	100 mm 01 No. 01 No.	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 LPM 40 mtrs Required Required	Provided Provided Provided Provided	MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A Required N/A 10000 ltrs	N/A N/A Provided N/A Provided	N/A N/A MR N/A MR
15.	Exit Signage.	Required	Provided	MR


16. Provision of Lifts.		(Restaurant is at UGF only)		
<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18. Refuge Area.				
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19. Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/EH/2018/SZ/1093 dated 16.05.2018 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of Inspecting Officer
 Name:- R.K.Yadav
 Designation:- ADO (JKP)

DO(South West)


 31/12/2020
 Dy cfo (S2)

F. F. please.

A D O (J K P)