

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/SZ/2021/ 35

Dated: 13/01/2021

FIRE SAFETY CERTIFICATE

Certified that the Air Force Senior Secondary School located at OWC, Race Course, New Delhi-110003, comprised of Ground Floor only, owned / occupied by Air Force Senior Secondary School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/Educational/SZ/2017/School/866 dated 16/06/2017. The premises was re-inspected by the officer concerned of Fire Service on 01.01.2021 in the presence of Mrs. Kavitha Menon (HOS) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Directorate of Education, Circular No. 3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class Educational (Group-B) **(Excluding Audi)** with effect from 13/01/2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to the compliance of the condition under rule 38 of the DFS rule, 2010.

Issued on 13/01/2021 at New Delhi by.



(SUNIL CHAUDHARY)

DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Mrs. Kavitha Menon (HOS), Air Force Senior Secondary School, OWC, Race Course, New Delhi-110003.
2. The Director of Education, SDMC, Civic Centre, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. **Fire Safety Certificate is not valid for Auditorium and it may not be used for any school activities until the required Fire Safety measures are provided.**
2. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
9. There shall not be more than 45 students in class rooms in any case.

41-8
INSPECTION REPORT

1. Name & address of the building: **Air Force Senior Secondary School, OWC, Race Course, New Delhi-110003.**
2. Type of Occupancy : **Educational (Ground Floor only)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/Educational/SZ/2017/School/866 dated 16/06/2017**
5. Fire Safety directives Letter No. : **DOE Circular no. 3298-3398 dated 01.03.2011**
6. Date of inspection : **01/01/2021**
7. Name of the Inspecting Officer : **A.D.O. (S.J.)**
8. Name and designation of Officer from the building side : **Mrs. Kavitha Menon (HOS)**
9. Year of Construction : **1987**
10. Applicant's letter through email **ID-afschoolracecourse@yahoo.co.in** dated 14/12/20

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circ. Dated 01/03/11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	6m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A		
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A		
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	25	50	MR
	• Types	ABC/CO ₂	Provided	M/R
	• ISI marking	Required	Provided	M/R

[Handwritten Signature]

6.	First – Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A

15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- 1. Fire Safety Certificate is not valid for auditorium as Fire Safety measure are not provided in this auditorium. Auditorium building is separate from school building.

2. General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route Clear.....
2. LPG cylinders in laboratories Nil.....
3. Electric wiring ... Conduit Wiring..... MCB and ELCB
Electric circuit
4. Electric meter board Not under the staircase.....
5. Basement use as per BBL 1983 NA.....
6. Emergency telephone no. board Displayed.....
7. Generator set Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/Educational/SZ/2017/School/866 dated 16/06/2017** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok Kumar
7/11/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

DO (SD) on leave

Dy C/O (S/R)

ADP/S.T
F.T. as advised to