

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/BNQT/SZ/2021/ 12

Dated: 08./01/2021

FIRE SAFETY CERTIFICATE

Certified that **Banquet Hall at Essex Farms Pvt. Ltd.**, located at **4 Aurobindo Marg, New Delhi- 110016**, comprised of ground floor only have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 12/12/2020 in the presence of Mr. R. N Mathur (Manager) and that the premises is fit for occupancy class "**Assembly Building**" (Banquet Hall) with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 08 / 01 /2021 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi.
2. The Legacy Banquet, Hall, M/s "Essex Farms Pvt. Ltd, 4 Aurobindo Marg, New Delhi 110016.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

1	Name & Address of the Building	Banquet Hall (New) Essex Farm Pvt. Ltd, located at 4, Aurobindo Marg, New Delhi-110016		
2	Type of Occupancy	Assembly 'Group-D' (Banquet Hall)		
3	Building comprised of	Ground floor only		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	NBC / UBBL 2016		
7	Date of Inspection	12/12/2020		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. R N Mathur (Manager)		
10	Year of construction	2011		
11	Applicant letter No.	DHO/SZ/2020/D-732 dated 16-09-2020		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / UBBL-2016	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	06 m ✓	MR
	• Gate width	05 mtr	4.5 mtr	MR
	• Width of internal road	NA	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	N/A	N/A	N/A
	• Basement floor	-NA-	N/A	N/A
	b. Width of Staircase			
	• Upper floors	-NA-	N/A	N/A
	• Basement floor	-NA-	N/A	N/A
	c. Protection of exits			
	• Fire check door	-NA-	N/A	N/A
	• Pressurization	-NA-	N/A	N/A
	d. No. of continuous staircase to terrace	-NA-	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 mtr & 1.50 mtr ✓	02 mtr, 1.6 m x 2 & 1.15 mtr ✓	MR
3	Compartmentation.			
	• Fire check door.	-NA-	N/A	N/A
	• Sealing of electrical shafts.	-NA-	N/A	N/A
	• Fire rating of shaft door.	-NA-	N/A	N/A
	• Water curtain	-NA-	N/A	N/A
	• Fire dampers.	-NA-	N/A	N/A
4	Smoke Management system.			
	• Basement	-NA-	N/A	N/A
	• Upper floors	-NA-	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers	04 no's	06 No's ✓	MR
	• Types	ABC / CO2	ABC & Co2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided ✓	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	Provided	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooper's location	-NA-	-NA-	-NA-

9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	100 mm	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	Required	02	MR
	<ul style="list-style-type: none"> Hose box. 	Required	02	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Head of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto Starting / Manual Stopping. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Pump House Access 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	40 mtr	40 m	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided	MR
14	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Access to tank. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Overhead tank capacity. 	20,000 Ltr	20,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's switch. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift signage. 	-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector System Panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Flow Switch Panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> PA system Panel. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Battery backup 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Building floor plan 	-NA-	-NA-	-NA-
20	Special Fire Protection System for the	-NA-	-NA-	-NA-

N/4

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules. The FSC is recommended under Rule 35 (3) of DFS Rules 2010

Accordingly, DFA is put up for approval and signature please.

[Handwritten signature]
15/12

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO (BCP)

~~DO/SO~~

~~ADP~~
15/12

~~DeFO/S2~~

~~[Signature]~~
15/12

GFO

Re speak

~~[Signature]~~
17/12

~~DeFO/S2~~

stokon

~~[Signature]~~

Director
11/1/2021

fi PL

