

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/SZ/2021/ 16

Dated: 11 / 01 / 2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Celebi Delhi Cargo Terminal Management India Pvt. Ltd. (Export & Import House) located at IGI Airport, New Delhi-110037, comprised of Ground and One Upper Floors has already been issues FSC by this department vide letter no. F6/DFS/MS/SZ/2018/196 dated 31/01/2018. The premises was re-inspected by the officers concerned of this department on 07.01.2021 in the presence of Mr. Rakesh Kumar (Sr. Executive, Fire & Safety) and found that the said building blocks have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building block is deemed fit for occupancy class "Storage" (Group-H) with effect from ____ / ____ /2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to the compliance of the condition under rule 38 of the DFS rule, 2010.

Issued on _____ **at New Delhi by.**

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Mr. Rakesh Kumar (Sr. Executive, Fire & Safety), M/s Celebi Delhi Cargo Terminal Management India Pvt. Ltd. (Export & Import House), IGI Airport, New Delhi-110037.
2. Sh. Hrishikeshan, GM (Fire), New Uddan Bhawan, Terminal-3, Airport, New Delhi-110037.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: **M/s Celebi Delhi Cargo Terminal Management India Pvt. Ltd. (Export & Import House), IGI Airport, New Delhi-110037.**
2. Type of Occupancy : **Storage (Group -H)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/SZ/2018/196 dated 31/01/2018**
5. Fire Safety directives Letter No. : **F6/DFS/MS/BP/380 dated 20/02/1998**
6. Date of inspection : **07/01/2021**
7. Name of the Inspecting Officer : **Dy. C.F.O. (S.Z.) & A.D.O. (S.J.)**
8. Name and designation of Officer
from the building side : **Mr. Rakesh Kumar (Sr. Executive, Fire & Safety)**
9. Year of Construction : **1988**
10. Applicant's letter received through email ld-rakesh.kumar@celebiaviation.in dated 24/12/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements / Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9m	Provided	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	5 Nos	14 Nos (8 Nos on city side & 6 Nos on Air side)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.25m	(3 x 1.5m, 2 x 1.7m, 1.3m, 1.4m, 1.12m & 5 x 1.3m, 1.25m)	MR (Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	Provided	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.25m	1.5m	MR
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	E. Fan Provided	MR
5.	Fire Extinguishers			
	• Total numbers	300	Provided	MR
	• Types	ABC, W.CO2, CO2 & Foam	150/80/60/10	MR
	• ISI marking	Required	Provided	MR

	• Total numbers on each floor	Gf-54, FF-20	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	6 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke & Heat	Smoke, Heat & Beam	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Required	FCC (T-3)	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	All Floors	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	Gf-54 , FF-20	Provided	MR
	• Hose Box	GF-54, FF-20	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	16	Provided	MR
	• Hose Box	16	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	4500 LPM	Provided	MR
	➤ Head of main pump	88 m	Provided	MR
	➤ Number of main pumps	2	Provided	MR
	➤ Jockey pump out put	2 x 450 LPM	Provided	MR
	➤ Jockey pump head	88 m	Provided	MR
	➤ Standby Pump out put	4500 LPM	Provided	MR
	➤ Standby Pump Head	88 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	9,00,000 ltr	7,50,000 ltr	MR (Old Case)
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank	N/A	N/A	N/A


15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	HVVSS for transformer & clean agent automatic flooding in HT & LT panels	MR

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/SZ/2018/196 dated 31/01/2018** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Signature of the Inspecting Officer
Name : Sunil Chawdhary
Designation : Dy.C.F.O.(S.Z.)



Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : A.D.O. (S.J.)

F.T. pleam -



A.D.O. (S.J.)

Sir, F.T. is added pl.



ty co/s 3