

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6 DFS/MS/School/2020/SZ/32

Dated: 13 / 01 / 2020

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Co-ed Secondary School, Neb Sarai, New Delhi, 110068** comprised of ground plus One upper floors was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/103 Dt. 18/01/2018. The said premises was re-inspected by officer concerned of this department on 11/12/2020 in presence of Sh. S. K Ghosh (Vice- Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 13 / 01 / 2020 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 13 / 01 / 2020 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Principal, Govt. Co-ed Secondary School, Neb Sarai, New Delhi, 110068
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	Govt. Co-ed Secondary School, Neb Sarai , New Delhi-110068 (ID-1923031)		
2	Type of Occupancy	Educational		
3	Building Comprised of	Ground plus one upper floor(2blocks)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/103 Dt. 18/01/2018		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	11/12/2020		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. S.K Ghosh		
10	Year of construction	1997		
11	Applicant letter No.	Gmail ID Dated 03/12/2020		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6mtr -NA- -NA-	6 mtr 4.5 mtr -NA-	MR -NA- -NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Old Block – 02 New Block - 01	Old Block – 02 New Block - 01	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5 m/ 0.75 m	Old Block – 1.50 m each New Block – 1.80 m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	One in each block	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30a/c per hour 12a/c per hour	-NA- -NA-	-NA- -NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	09 no's Required CO ² &ABC ISI mark	12 Nos ABC Type Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. 	-NA- -NA-	-NA- -NA-	-NA- -NA-

19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/103 Dt. 18/01/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Sh. Rajesh Kumar

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

20/1/20
14/1/20
Defo (SZ)
F.T. p. checked
Sh

M-S-11
f.t. letter is put up for your signature
Sh
14/1/20
20/1/20
Sh

M-S-11