

c/8

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/School/WZ/2021/ 43

Dated: 13/01/2021

**FIRE SAFETY CERTIFICATE**

Certified that **Govt. Sarvodaya Bal Vidyalaya (New Building) located at Peera Garhi Village, New Delhi- 110087** is comprised of ground plus three upper floors was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/WZ/2017/1239 dated 21/08/2017. The school building was re-inspected by the officer concerned of this department on 15/12/2020 in presence of Sh. Dharampal, Estate Manager of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the under mentioned conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on 13/01/2021 at New Delhi by.

  
(DHARAMPAL BHARDWAJ)  
Dy. CHIEF FIRE OFFICER (WZ)  
DELHI FIRE SERVICE

Copy to: -

1. The H.O.S, Govt. Sarvodaya Bal Vidyalaya, Peera Garhi Village, New Delhi- 110087.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054.

### Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

1. Name & address of the building : Govt. Sarvodaya Bal Vidyalaya (New Building) located at Peera Garhi Village, New Delhi- 110087.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2017/1239 dated 21/08/2017
5. Fire Safety directives letter No : N/A
6. Date of inspection : 15.12.2020
7. Name of the Inspecting Officers : Aman Kumar Lathar, Asst. Divisional Officer (JWP)
8. Name and designation of officers from the building side : Sh. Dharampal, Estate Officer
9. Year of Construction : 2016-17
10. Applicant's letter No. : SBV/PG/2020/02 dated 24.08.2020.

The said school building is comprised of ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 mts	Provided	MR
		4.5 mts	Provided	MR
		N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 Nos.	02 Nos.	MR
		N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.5 mts	1.85 mts each	MR
		N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 mts	Provided	MR
	h. Door Size	1.0 mt.	Provided	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	N/A	N/A
		12 a/c per hour	Natural ventilation provided	MR



16		Not Applicable		
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18 Refuge Area.				
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19 Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/WZ/2017/1239 dated 21/08/2017, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

DFA is put up for approval & signature please.

*Aman Kumar Lathar*  
21/12/20.

Signature of the Inspecting Officer  
(Aman Kumar Lathar)  
Asst. Divisional Officer (JWP)

DO (West Division)

D.O. (WEST) 03  
DATED 21/12/2020

*[Signature]*  
21/12/2020

DO (WZ)

*[Signature]*

F.T. letter is put up for signature please.