

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2020 / EH / W2 / 02

Dated: 01/01/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s KFC Restaurant (A Unit of Sapphire Foods India Pvt. Ltd.) located at **Ground floor, Property no. 38 UA, Bunglow Raod, Kamla Nagar, Delhi-110008** in the building comprised of Ground, Mezz + 02 upper floors owned/ occupied by M/s **Sapphire Foods India Pvt. Ltd. Restaurant** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **15.12.2020** in the presence of **Sh. Madhur Sharma** and that the building/ premise is fit for occupancy Class **Assembly** restaurant at **ground floor only** with effect from 01/01/2021 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/01/2021 at New Delhi by



(Atul Garg)

Director

Ph-011-23414000

etc

Copy to:-

1. M/s KFC Restaurant (A Unit of Sapphire Food India Pvt. Ltd.), 38, UA, Ground Floor, Bunglow Road, Kamla Nagar, Delhi-110008.
2. The Dy. Health Officer, NDMC, Public Health Department City S.P. Zone, Old Hindu College, Kashmere Gate, Delhi.
3. Joint CP (Lic.) P.S. Defence Colony, New Delhi (Ref. Application no. 20201203190117).

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s KFC Restaurant (A Unit of Sapphire Food India Pvt. Ltd.), 38, UA, Ground Floor, Bunglow Road, Kamla Nagar, Delhi-110008.
2. Type of Occupancy : Assembly (Ground floor only) Ground, Mezz & 02 upper floor
3. Type of Case : New Case **Ground floor- Restaurant**
4. Details of previous NOC : Nil **Mezz- Vacant**
5. Fire Safety directives letter No : Nil **First Floor-Other Property**
6. Date of inspection : 15.12.2020 **Second floor- Other Property**
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Mr. Madhur
9. Year of Construction : 2000 (Residential) as per online application
10. Date of conversion of occupancy of the establishment proposed 01.07.2017 as per online application
11. Applicant's letter No. : Online I. D. no. 2020120308812 dated 04.12.2020

	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09m	12m approx...	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits (Restaurant at GF only)			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	1m	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2m & 1.50m	2.0m & 1.50m	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA

Fire Extinguishers		05nos	06nos	MR
	• Total numbers	ABC/Co2	ABC-5 Co2-1	MR
	• Types	Yes	Yes	MR
	• ISI marking			
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor(Ground floor)	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
➤ Head of the pump	40m	Provided	MR	

	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000ltr	20,000ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renewal Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.



K. Meena
21/12/2020
By CPO (W2)
CPO

Signature of the Inspecting Officer
Name: - C.L. Meena
Designation:- ADO/RN

16/12/2020

Signature of C.L. Meena

Signature of the Inspecting Officer
Name: - C.L. Meena
Designation:- ADO/RN