

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No. F.6/DFS/MS/GH/2021/SZ/ 18

Dated: 11/01/2021

FIRE SAFETY CERTIFICATE

Certified that Pankaj Guest House at 31, Nangli Rajapur East Nizamuddin New Delhi-110013, comprised of ground plus three upper floors was granted FSC for ground floor (Reception + 03 G/Rooms), 1st floor (03 G/ Rooms), 2nd floor (03 G/Rooms), 3rd floor (owner's residence) & terrace floor (Room Closed) by this department vide letter No. F6/DFS/MS/GH/2016/SZ/1605 Dated 31-10-2016. The premises was re-inspected by officer concerned of this department on 08/01/2021 in the presence of Sh. Pankaj (Manager) and found that the guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises is fit for occupancy class "Residential & Lodging Building, Group- A" (FSC renewed for ground floor (Reception + 03 G/Rooms), , 1st floor (03 G/ Rooms), 2nd floor (03 G/Rooms), 3rd floor (owner's residence) & terrace floor (Room Closed) with effect from 11/01/21 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 11/01/2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Pankaj Guest House at 31, Nangli Rajapur East Nizamuddin New Delhi-110013
2. Joint Commissioner of Police, Licensing Branch, 1st floor P.S. Defence Colony, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule of 2010. The form is available on www.dfs.delhigovt.nic.in.
5. The certificate may not be treated in any case for the regularization (clause 2.8 & UBBL-2016) of the unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

1	Name & Address of the Building	Pankaj Guest House at 31, Nangli Rajapur East Nizamuddin, New Delhi-110013		
2	Type of Occupancy	Residential & Lodging, Group-A (Guest House)		
3	Building Comprised of	Ground + 3 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/GH/2016/SZ/1605 dated 31-10-2016		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	08/01/2021		
8	Name of the Inspecting Officers	ADO Avtar Singh		
9	Name & Designation of Officers from the building side	Mr. Pankaj (Manager)		
10	Year of construction	1991	Ground floor (Rec.+ 03 G/Rooms), 1 st floor (03 G/Rooms), 2 nd floor (03 G/Rooms), 3 rd floor (owner residence) & terrace floor- Generator room	
11	Applicant letter No.	Email dated:- 07/01/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC 04/10/2013 Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 m	6 m	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	One	One	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1 m	1 m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	One	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	2m (final exit)	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	06 Nos.	06 Nos.	MR
	• Types	ABC / W.CO2	ABC-03 & W.CO2-03	MR
	• ISI Marking	ISI marked	Provided	MR

	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose-reel hose. 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle Diameter 	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Carbon Monoxide (CO) type	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Repeater Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Alternate source of power 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hooter's location 	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of Hydrant per floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Head of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of main pumps. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Jockey Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Jockey Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Standby Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Standby Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Auto Starting/Manual Stopping. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pump house access. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. 	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> Head of pump. 	40 mtr	40mtr	MR
	<ul style="list-style-type: none"> Power supply. 	Required	Provided (Invertor)	MR
	<ul style="list-style-type: none"> Auto starting of pump. 	Required	Provided	MR
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Draw-off connection. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Service Inlet. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Access to tank. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Overhead tank capacity. 	5000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-N/A-	-N/A-	-N/A-

	<ul style="list-style-type: none"> • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • 5. Lift signage. 	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	Required	Provided (Invertor)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	01 ABC type fire extinguisher provided near electric panel	MR

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection..

The condition of the Gazette notification dated 27/05/2019 on mentioned below found complied.

- | | | |
|--|----|----------------------|
| 1. No Kitchen on rooftop/basement. | MR | No Kitchen Provided |
| 2. No Storage of inflammable material on rooftop. | MR | No Storage Provided |
| 3. No temporary roofing over the rooftop. | MR | Not Provided |
| 4. No Inflammable material of construction in passage/corridor. | MR | Not Provided |
| 5. Gas Bank, if any. | MR | No Gas Bank provided |
| 6. Carbon Monoxide type Detectors. | MR | Provided |
| 7. Fire Doors of min. 01 hr. rating
(If number of occupants more than 10 on each floor) | MR | Not Required |

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/GH/2016/SZ/1605 dated 31/10/2016, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

(Signature)
08/11/2021

Signature of the Inspecting Officer
Name : Avtar Singh
Designation: ADO (M.RD)

DO (SD)

*On leave + D/off
Et. please*

DUFO (SR)

*(Signature)
AD (MR) FI letter issued up for sign.*