

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/Restaurant/2020/NDZ/ 31

Dated: 07/11/2021

To,

The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s CAFÉ G2 (A unit of Black Pepper Hospitality Event Pvt. Ltd.) at Plot No.3 at CBD Shahdara, Delhi-110032.

Sir,

With reference to your online application ID No. 2020101407694 dated 16/11/2020 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned restaurant from fire safety point of view in presence of Mr. Arora. During the course of inspection the following shortcomings were observed.

1. An additional Exit door of 1.50 meters width is not found provided.
2. First Aid Hose reel is provided but not found functional at the time of inspection.
3. MOEFA is provided but not found functional at the time of inspection.
4. Down-comer is provided but not found functional at the time of inspection.
5. Exit signages are not found provided.
6. The temporary structure adjacent to the restaurant should be removed.


In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Hence the application is rejected.

Yours faithfully



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

Mr. Anoop Arora
Flat No. 01021,
Tower ATS Apartment,
Indra puram, Gaziabad,
Uttar Pradesh-201014

ID No. 2020101407694 dated 16/11/2020