

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No.F6/DFS/MS/WZ/2021/

Dated: - 08/01/2021

52

To,

Sh. Pankaj Gupta,  
M/s. Royal Peppar Banquet Hall,  
C-94, Wazirpur Industrial Area,  
Delhi-110052,

**Sub:- Renewal of Fire Safety Certificate in respect of M/s. Royal Peppar Banquet Hall,  
Located at C-94, Wazirpur Industrial Area, Delhi-110052**

Sir,


This has reference to your email dated 22.12.2020 on the subject cited above. In this connection it is to inform you that the above said assembly building has been inspected by the officer concerned of this department from Fire safety point of view on 31.12.2020 in presence of Sh. Parvash Mishra (Manager).

**During the course of inspection the following shortcomings have been observed:**

1. One Exit at Upper Floor found Closed.
2. Fire Check Door found damaged.
3. Smoke Management system provided at all Floors is inadequate and not interlinked with Fire alarm system.
4. PA system found nonfunctional.
5. Internal Hydrant system is provided but some adaptors missing.
6. Hose Box near yard hydrant found missing.
7. Fire Pumps not on auto operation due to leakage in pipe line.
8. Exit signage's removed at some places.

In view of the above shortcomings, fire safety certificate cannot be renewed at this stage. You are advised to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to:-

1. The Addl. Commissioner of Police (Lic), 1<sup>st</sup> Floor, Licensing Unit, Police Station, Defence Colony, New Delhi
2. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.