

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No.F6/DFS/MS/2021/CNG/WZ/ 32

Dated:- 15/01/2021

FIRE SAFETY CERTIFICATE

Certified that the **CNG Dispensing Station** located at **Shahabad Dairy, Sec-30, Rohini, Delhi** comprised of **Ground + First Floor** owned/ occupied by **Indraprastha Gas Limited** was granted NOC by the department vide letter no. **F6/DFS/MS/2017/CNG/503 Dated: 03.04.2017**. The premises was re-inspected by officer concerned of this department on **29.12.2020** in the presence of **Mr. Prashant Kumar (AM)** and that the premises have deemed complied with fire prevention & fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premises is fit for **occupancy CNG Filling Station Group 'J'** with effect from 15/01/2021 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed below.

Issued on 15/01/2021 at New Delhi by


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

o/c
CNG

Copy to: -

1. Chief General Manager (Project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Centre, R.K. Puram, Sec-09, New Delhi-110022.
2. The Addl. Commissioner of Police (Lic), 1st Floor, Police Station, Defense Colony, Delhi

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use for land if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

1. Name & address of the building : CNG Dispensing Station at Shahabad Dairy, Sec-30, Rohini, Delhi
2. Type of Occupancy : CNG Filling station **Group 'J'** (G +1)
3. Type of Case : Old Case *Renewal*
4. Details of previous NOC : F6/DFS/MS/2017/CNG/503 Dated: 03.04.2017
5. Fire Safety directives letter No : F.6/DFS/MS/CNG/2012/723 Dated: 29.12.2012
6. Date of inspection : 29.12.2020
7. Name of the Inspecting Officers : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
from the building side : Mr. Prashant Vihar (AM)
9. Year of Construction : 2012
10. Applicant's letter No. : Online mail dated 01.12.2020


	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	30m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.10 mtr	1.10 & 0.95 mtr	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	Required	1.0m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			

N-19

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.			
		NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply			
		NA	NA	NA
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Fire buckets filled with sand, No smoking boards were found displayed in Hindi & English. No loose electric wiring were seen in premises & Co2 flooding system found provided		MR


The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter no. F6/DFS/MS/2017/CNG/503 Dated: 03.04.2017 under rule 37 of the Delhi Fire Service Rules 2010


 29/12/2020
 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO (Rohini)

DO(NW)

P1. check the add on DFA of fsc & re-submit


 04/01/2021