

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/2020/ 07

Dated:- 05/01/2021

To,

The Principal,
Albert Einstein Public School,
E-Block, Gali No. 11,
Sonia Vihar, Delhi-110094

Sub:- Application for Issuance of School Fire Safety Certificate.

Sir,

With reference to your letter dated 05/10/2020 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Deepanjali, Principal of the School on dated 19/11/2020. The School building comprises of ground plus two upper floors. During the course of inspection following observations were made:-

1. A fire pump with 450 liters per minute discharge at 40 meters head (4kgf/sq.cm.) is required to be provided at terrace level.
2. An overhead water tank having 10,000 liters is required to be provided exclusively for fire fighting systems.
3. Staircase of width 1.50 meter is required to be provided in the building.
4. Sanctioned/as built plan showing fire fighting arrangements by registered architect to be submitted.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned fire safety arrangements under intimation to this office for further necessary action.

Yours Faithfully,


4/1/21

(Dr. S.K. Tomar)

Dy. Chief Fire Officer
Ph. No. 011-23412025


21

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi -110053