

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2021/SZ/ 21

Dated: 11 / 01 / 2021

To

The Principal,
Gyan Jyoti Vidya Niketan,
W-21, Anupam Garden,
Saidulazab New Delhi 110068

Sub: Issue of Fire Safety Certificate in r/o Gyan Jyoti Vidya Niketan, W-21, Anupam Garden,
Saidulazab New Delhi 110068


Sir,

This is in reference to your Gmail dated 19-09-2020, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Sh. Navdeep on dated 12-12-20 to verify the compliance of the shortcoming issued by this department vide letter no F6/DFS/MS/School/SZ/2017/2137 dated 18/08/2017. The shortcomings have not been complied so far. However the status of shortcoming observed is as below.

1. Width of staircase provided in block 1 & 2 is 1.50 mtr & 1.10 mtr respectively against the required width 1.50 mtr.

Keeping in view of above, the Fire Safety Certificate cannot be issued at this stage in the interest of public safety.

Yours faithfully,


(Atul Garg)
Director

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054