

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DEL HI

No. F6/DFS/MS/WZ/2020/ 12

Dated: 05/01/2020

To,

The Principal,
Kendriya Vidyalaya,
Tagore Garden, Delhi-110027,

Subject: Regarding issuance of Fire Safety Certificate in r/o Kendriya Vidyalaya Located at Tagore Garden, Delhi


Sir,

This is in reference to the Email dated -11/12/2020. Regarding renewal of Fire safety Certificate in respect of the above mentioned school building. in this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 17/12/2020 in presence of Sh. Mukesh Kumar (Principal). During the course of inspection, the following shortcomings were observed:

1. Hydrant & Hose Reels is found nonfunctional and damage.

In view of the above shortcoming Fire safety certificate cannot be considered at this stage You are requested to comply the above mentioned shortcomings under to this department.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to: -Directorate of Education Old Secretariat Delhi – 110054