

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2021/ 18

Dated: 06 /01/2021

To

The Principal,
Kerla Education Society Regd. Senior Secondary School,
Srimat Madhav Rao Scindia Marg, (Canning Road), New Delhi.

Sub: Regarding Renewal of FSC in r/o Kerala Education Society Regd. Senior Secondary, School at Srimat Madhav Rao, Scindia Marg, (Canning Road), New Delhi.

Sir,

This has reference to your e-mail <keralaedusoc@gmail.com> dated 17/12/2020, on the subject cited above. In this regard, it is to inform you that the site was inspected by ADO(CC) & DO(CD) of this department on 30.12.2020 in the presence of Mr. Hari Kumar. K.G. (Principal) and the following shortcomings are observed.

1. First aid hose reel found nonfunctional.
2. Hydrant found nonfunctional.
3. Terrace pump found nonfunctional.
4. Exit signage found inadequate.

In view of above, fire safety certificate (FSC) cannot be renewed.

Yours faithfully


5/1/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.