

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. *f6/Dfs/ms/school/2021/17*

Dated: *05/01/2021*

To,

The Manager,  
S.G.T.B. Khalsa Girls Sr. Secondary School,  
Aliganj, Lodhi Colony, New Delhi-110003.


**Sub.:- NOC in r/o S.G.T.B. Khalsa Girls Sr. Secondary School, Aliganj, Lodhi Colony,  
New Delhi-110003.**

Sir,

With reference to your letter No. F 162/2020/66 to 67 dated 04.09.2020 on the subject noted above, in this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 05/12/2020 in the presence of Smt. Kulvinder Kaur and observed that at present building comprised of Ground Floor, 1<sup>st</sup> Floor & 2 rooms on terrace floor (2<sup>nd</sup> Floor). However previous NOC / FSC was issued to this premises vide letter No. F6/DFS/MS/School/SZ/2017/1491 dated 16/10/2017 for **Ground Floor & One Upper Floor only**. This is a case of addition / alteration, hence NOC /FSC cannot be considered at this stage.

You are requested to either remove / dismantle rooms on terrace or provide 2 staircase of width 1.50mtr each and also extend Fire protection measures as per NBC- Part (IV) on terrace.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR.

Copy to:-

1. The Director of Education, SDMC, Civic Centre, New Delhi.

*Atul Garg*