

477

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2020/ 13

Dated: 05/01/2021

To,

The Principal,
Yuva Shakti Model School,
Budh Vihar, Delhi-110086.

Sub: Issuance of Fire Safety Certificate in r/o Yuva Shakti Model School, Budh Vihar, Delhi-110086.

Sir,

Kindly reference to online mail dated 21.07.2020, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mrs. Madhu Rajouria (Vice-Principal) on 21.12.2020 to verify the compliance of fire prevention and fire safety measures required under the rules. Following shortcoming has been observed during inspection.


1. Terrace floor door found opening in wards in contravention NBC/UBBL.
2. Hose reel Nozzle found removed at some places.
3. Terrace pump of 450 lpm is provided but not functional.
4. 2000 ltrs Over Head water captive tank provided against the required capacity of 2500 ltrs.
5. School building found extended beyond boundary walls, Therefore you are advised to submit the approved building plans.

In this regard as stipulated in sub Rule (1) of Rule 37 of DFS Act-2007 & Rules 2010 you are advised to apply again in Form "I" along with a certificate from Architect/ owner that all the fire prevention and fire safety measures are provided as per Rule 33 of DFS Act-2007/ Rules 2010 in the building/premise & duly filled Performa enclose herewith. The Form "I" is available on website of this department under.

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours Faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

all
by