

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F.6/DFS/MS/School/SZ/2020/ 23

Dated: 12/01/2021

To,

The Principal  
Govt. Girls Sr.Sec. School no-2  
Badarpur, New Delhi-110044

**Subject: Regarding renewal of Fire safety Certificate in r/o Govt. Girls Senior Secondary School, No-2, Badarpur, New Delhi-110044**


Sir,

This is in reference to your letter no. GGSSS no.2/Bdr/1667 dated 26/10/2020 received in this department through Outdoor Diary no. 8520 dated 28/10/2020 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on 23/12/2020 in the presence of Ms Kamakshi Jolly (Vice-Principal). The following shortcomings have been observed:

1. Hose reels are found nonfunctional.
2. Terrace Fire pump found nonfunctional.
3. Overhead tank is missing.
4. Exit Signage is missing at some places.

Keeping in view of above, Fire Safety Certificate cannot be considered at this stage

Yours faithfully

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

o/c Az

Copy to:-

1. The Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002