

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2020/ 19

Dated: - 07/01/2021

To,

O/o Assistant Engineer (E),  
Education (Maint.) Sub. Divn M 1-1,  
PWD GNCT, Govt. of Delhi  
ITI Campus Pusa Road ,New Delhi

Sub.: - Regarding issuance of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya, Ranjit Nagar, New Delhi- 08.

Sir,

Please refer to your letter No. letter No. 54(SPS School)/PWD Edu.Sub-Divn M1-1(N)/2020-21/041 dated 29.10.2020 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Mr. Sourav Gupta, JE ( Electrical), of the School on 16.12.2020 to check the fire safety arrangements already installed in the building.

During inspection, it has been observed that the said school management has constructed one new block comprised of ground plus three upper floors served by three nos. of staircases having width 1.66 mts, 1.74 mts & 1.74 mts respectively. Fire safety arrangements such as hose reel, terrace pump, overhead water tank, fire extinguishers etc. found provided in the school building. However, the following shortcomings were observed in the New building of the school: -

1. Terrace Pump is not on Auto Mode..
2. Each class room is provided with two doors , one is opening inward side & other is opening outward side ( in corridor). Door which is opening outward side ( in corridor) width of corridor remains 130 cms instead of 150 cms.
3. Exit signs are not provided.
4. Door width is less than 120 cms.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi
2. The Executive Engineers (E), Division M1, ITI Campus Pusa New Delhi
3. The Principal, Sarvodaya Kanya Vidyalaya, Ranjit Nagar, New Delhi- 110008
4. M/s Arihant Building T-96, OM Vihar, Uttam Nagar, New Delhi-110059 (Main Agency) for information please