

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/SZ/2021/ 41

Dated: 13 / 01 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Vidyalaya (Rani Durgawati ID:1924039) located at East Kidwai Nagar, New Delhi-110023, comprised of Ground & Four Upper Floors only, owned / occupied by Sarvodaya Vidyalaya, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/2016/SZ/574/512 dated 12/04/16. The premises was re-inspected by the officer concerned of Fire Service on 14.12.2020 in the presence of Smt. Vandana Bhardwaj (Vice Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class Educational (Group-B) with effect from \_\_\_\_\_ / \_\_\_\_\_ /2020 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to the compliance of the condition under rule 38 of the DFS rule, 2010.

**Issued on \_\_\_\_\_ at New Delhi by.**

  
(ATUL GARG)  
DIRECTOR.

Copy to :-

1. Head of School, Sarvodaya Vidyalaya, (Rani Durgawati ID:1924039), East Kidwai Nagar, New Delhi-110023.
2. Dy. Director, Education (South East) GNCT of Delhi, C-Block, Defence Colony, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. There shall not be more than 45 students in class rooms in any case.

# INSPECTION REPORT

1. Name & address of the building: **Sarvodaya Vidyalaya (Rani Durgawati ID:1924039), East Kidwai Nagar, New Delhi-110023.**
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground & 4 Upper Floors)
4. Details of previous NOC : F6/DFS/MS/2016/SZ/574/512 dated 12-04-16
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2013/308 dated 08/10/2013
6. Date of inspection : 14/12/2020
7. Name of the Inspecting Officer : A.D.O. (S.J.)
8. Name and designation of Officer from the building side : Smt. Vandana Bhardwaj (Vice Principal)
9. Year of Construction : 2016
10. Applicant's letter received through Email [ID-svina1924039@gmail.com](mailto:ID-svina1924039@gmail.com) dated 18/08/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	6 m	MR ✓
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	6 m	6 m	MR ✓
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50m (Each)	1.50m x 3 ✓	MR ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR ✓
	e. Width Of Corridor	1.50 m	1.50 m ✓	MR
	f. Door Size	1.00 m	1.00 m ✓	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR ✓
5.	Fire Extinguishers			
	• Total numbers	10	16 ✓	M/R
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	M/R
	• IS marking	Required	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- General requirements for schools.

1. Escape route ..... Clear.....
2. LPG cylinders in laboratories ..... Nil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB .....
4. Electric meter board .....Not under the staircase.....
5. Basement use as per BBL 1983 .....NA.....
6. Emergency telephone no. board .....Displayed.....
7. Generator set ..... Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2016/SZ/574/512 dated 12/04/2016 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

~~DO (SD)~~

*[Signature]*  
22/12/2020

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (S.J.)

*[Handwritten notes]*  
dine 23/12 Pl. speak

*[Handwritten notes]*  
DISO (S.J.)

*[Handwritten notes]*  
A D O S. J. spoken

